

 GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2026/ 380

Dated: 24/04/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Arya Tourist Lodge Guest House, 8526, Arakashan Road, Ram Nagar, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026033003844 dated 30/03/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 09/04/2026 in the presence of Sh. Varun Pahuja, Owner and following shortcomings were observed: -

1. Fire Check door was not provided at Ground Floor.
2. Smoke Management system provided but found non-functional.
3. Manually Operated Electronic Fire Alarm (MOEFA) provided but found non-functional.
4. Automatic operation of Fire pump found removed.
5. Domestic connection provided in Overhead Water storage tank is not permissible.

Keeping in view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands rejected. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,


(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

01c638

Copy to: -

1. The Manager, M/s Arya Tourist Lodge Guest House, 8526, Arakashan Road, Ram Nagar, Paharganj, New Delhi - 110055.