

C49

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No.F.6/DFS/MS/School/2025/WZ/59

Dated: 24/01/2025

FIRE SAFETY CERTIFICATE

Certified that the **Arya Veer Model School, A-38, Badli Extension, Delhi-110042**, comprised of basement, ground + 04 upper floor but school running at **Ground + 04 upper floors** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/School/2022/WZ/347** dated **31.03.2022**. The premises was re-inspected by the officer concerned of this department on **14.01.2025** in the presence of **Sh. Mahender Pal Manchanda (Owner)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy Class **"Group B Educational"** with effect from 24/01/2025 for **(Ground + 04 upper floors only)** a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24/01/2025 at New Delhi

(Atul Garg)
DIRECTOR

Ph; 011-23414000

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Principal, Arya Veer Model School, A-38, Badli Extension, Delhi-110042.
3. The Commissioner, MCD, Minto Road, Civic Centre, New Delhi, New Delhi-110002, for height information of building.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building	Arya Veer Model School, A-38, Badli Extension, Delhi-110042.			
2. Type of Occupancy	Educational			
3. Comprised of building	Basement + Ground + 04 upper floors			
4. Type of Case	Renewal (School running at Ground + 04 upper floors) basement sealed by owner given by undertaking C-33			
5. Details of Previous NOC	F.6/DFS/MS/School/2022/WZ/347 dated 31.03.2022.			
6. Fire Safety directives letter No	NBC Part-IV			
7. Date of inspection	14.01.2025			
8. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)			
9. Name and designation of officers From the building side	Sh. Mahender Pal Manchanda Owner			
10. Year of Construction	2015			
11. Applicant's letter No.	Online e-mail dated 23.12.2024			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			MR
	• Road width	Accessible	Accessible	MR
	• Gate width	Directly accessible	Directly accessible	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			MR
	• Upper Floors	02nos.	03nos.	-NA-
	• Basements	-NA-	Basement not in used and sealed	-NA-
	b. Width of staircases			MR(Old case)
	• Upper Floor	As per previous FSC	0.90m, 1.0m & 0.95m	-NA-
	• Basements	-NA-	Basement not in used and sealed	-NA-
	c. Protection of exits			-NA-
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	-NA-	02nos.	-NA-
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	1.0m	Provided	MR
3.	Compartmentation			-NA-
	a) Fire check door	-NA-	-NA-	-NA-
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			-NA-
	a) Basements	-NA-	Basement not in used and sealed	-NA-
	b) Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			MR
	a) Total numbers	10nos.	Provided	MR
	b) Types	ABC/CO2	ABC/CO2	MR
	c) IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			

	a) Total numbers on each floor	01nos.	Provided	MR
	b) Length of hose reel hose	30mm	Provided	MR
	c) Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	a) Type of detectors	-NA-	-NA-	-NA-
	b) Location of Main Panel	-NA-	-NA-	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	-NA-	-NA-
	e) Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	a) Basement	-NA-	Basement not in used and sealed	-NA-
	b) Ground & Upper Floors	-NA-	-NA-	-NA-
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	a) Size of riser/down-comer	-NA-	-NA-	-NA-
	b) Number of hydrants per floor	-NA-	-NA-	-NA-
	c) Hose Box	-NA-	-NA-	-NA-
12.	Yard Hydrants			
	a) Total number of hydrants	-NA-	-NA-	-NA-
	b) Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level	-NA-	-NA-	-NA-
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	450lpm	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	10,000ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-

N/27

	c) Communication In lift Car	-NA-	-NA-	-NA-
	d) Fireman's Grounding Switch	-NA-	-NA-	-NA-
	e) Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area.			
	a) Total Area	-NA-	-NA-	-NA-
	b) Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	a) Detector System Panel	-NA-	-NA-	-NA-
	b) Flow Switch Panel	-NA-	-NA-	-NA-
	c) PA System Panel	-NA-	-NA-	-NA-
	d) Battery backup	-NA-	-NA-	-NA-
	e) Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F.6/DFS/MS/School/2022/WZ/347** dated **31.03.2022** is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Signature of the Inspecting Officer
Name **Ajay Kumar Sharma**
Designation **ADO(Rohini)**

D.B Mukherjee
DO (NW)

DCFO/292-N/10
Dated 17.01.25
21.01.25

Dy cfo (R2)

If agreed, we may also issue a letter to MCD for height-verification being the building comprising of ground plus four upper floors. Accordingly DFR 6 amendment submitted please.

CFO

20/01/2025

Director

21/1/25

ADO(Rohini)

A. also apper

put up FT.

OLF/WL

21/1/2025