

C-174

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No. F6/DFS/MS/NDZ/2025/ 416

Dated:- 25.08.2025

To

Dr. Sanat Kaul Retd. IAS (President),  
Asha Deep, Apartment Owner's Housing,  
Maintenance, Co-Operative Society, 9, Hailey Road,  
New Delhi.

Sub: Regarding renewal of FSC in r/o Asha Deep Building, 9, Hailey Road, New Delhi.


Sir,

This has reference to your letter no. Nil Dated 18/07/2025 & received DFS diary no. 4042 dated 23.07.2025, on the subject cited above. In this regard, it is to inform you that the site was inspected by officer concerned of this department on dated 11.08.2025 in the presence of Sh. KC Singh estate Officer and the following shortcomings were observed:-

1. Hose reel found nonfunctional.
2. MCP found nonfunctional & glass found broken.
3. Some fire extinguishers found corroded need to be replaced with new one.
4. Smoke management system found nonfunctional in basement.
5. Lift signage's "not to use lift in case of fire" not installed.
6. Pump not in auto start provision.

In view of above, Fire Safety Certificate (FSC) cannot be renewed at this stage. Therefore, you are requested to rectify above shortcomings and re submit for further consideration in the matter.

Yours faithfully

  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service

Copy To

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.