



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/School/SZ/2025/202

Dated: 8/04/2025

To

The Principal,  
 Asha Ram Royal Public School,  
 Madanpur Khadar, Sarita Vihar, New Delhi-76.

**Sub:-** Regarding renewal of Fire Safety Certificate in respect of Asha Ram Royal Public School located at Madanpur Khadar, Sarita Vihar, New Delhi-76.

Sir,

With reference to the letter bearing outdoor diary no14554 dated 17.03.2025 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 28.03.2025 in the presence of Mr. Bhagat Singh (President) and it was observed that the building which was earlier comprised of Ground + 02 upper floors is now comprised of Ground + 03 upper floors. Hence is a case addition/alteration. During the inspection following shortcoming were observed.

1. Alternate staircases of 1.50 meters width from ground floor to terrace shall be provided.
2. The corridor width of 1.50 meters shall be provided at 3<sup>rd</sup> floor.
3. Hose reel found non functional.
4. Fire pump found non functional.
5. Overhead tank 10,000 liters not provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)  
 Director

Delhi Fire Service

02/4/25

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISTT. South Sector-3, R.K. Puram, New Delhi-22.