

c/14

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/School/2025/ 112

Dated: 17/02/2025

To,

Sh. Anoop Dhawan,  
Asha Ram Model School,  
Kh. No.136/2, House No.373, Badli,  
Delhi-110042.

**Sub:** Issuance of Fire Safety Certificate in r/o Asha Ram Model School, Kh. No.136/2, House No.373, Badli, Delhi-110042.

Sir,

Kindly reference to letter received in this department through outdoor diary no. 10880 dated 31.12.2024 on the subject cited above. In this connection it is to inform you that FSC provided by you along with form 'J' is a fake document, not issued by this department. Further, this department has already issued shortcoming vide letter no. 117 dated 05.04.2013 and no compliance of the shortcoming received by this department. Therefore, you are advised to comply the shortcoming already issue vide letter no.117 dated 05.04.2013 & re-apply in form 'I' for further consideration in this matter.

Yours Faithfully

(Atul Garg)

**DIRECTOR**

Ph; 011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54

25

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

**NO.** F6/2FS/MS/School/2013/1117

**Date:** 05/07/2013

To

The Principal,  
Asha Ram Model School,  
373, Vill. Badli Delhi 110042

**Sub:** - Regarding fire safety certificate in r/o Asha Ram Model School, 373, Vill. Badli  
Delhi-110042

Sir,

Please refer to your letter Nil Dated 20/02/2013 on the subject cited above. In this connection this is to inform you that the inspection of the above said premises was carried out by the officer concerned of this department along with school authority on 06/03/2013 from fire safety point of view and following shortcomings were observed.

1. Building is not accessible to fire units.
2. Stair case width is 75 cm against the required width of 1.5 m.

Keeping in view of the above fire safety certificate cannot be considered at this stage. You are requested to provide the fire safety arrangements as per the circular of Director of Education, issued vide letter no. F-16/estate/cc/fire safety/2011/3298-3398 dated 01/03/2011.

Yours faithfully

u  
3/4

By Chief Fire Officer  
Delhi Fire Service

**Copy to:** Director of Education, Old Sectt. Delhi for information

JCE