



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/CGHS/2025/SZ/196

Dated: 29/04/2025

To

The President,
The Ashiana CGHS Ltd
Plot No-10, Sector-6, Dwarka,
New Delhi-110075

Sub: Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o
The Ashiana CGHS Ltd at Plot No-10, Sector-6, Dwarka, New Delhi-110075.

Sir,

Please refer to your letter no NACGHS/Fire Fighting/NOC Dated 22/01/2025 on the subject cited above. In this connection it is to inform to you that the above said premises was inspected by the officer concerned of this department on 09/04/2025 in the presence of Sh. Ajay Kumar (President) from fire safety point of view. During the course of inspection followings shortcoming are observed: -

1. Six-meter-wide internal road around the building found encroached.
2. The trimming of trees is required to be done for free movement of fire vehicle in case of fire emergency.
3. Only one ABC type fire extinguisher of 5kg capacity is found provided at each floor against required two fire extinguishers.
4. Hoses & Branches are found removed at some places.
5. Terrace pump having capacity 450 lpm found removed.
6. Exit signage's & lift signage's found removed.

In view of the above shortcomings renewal of Fire Safety Certificate is rejected. & you are directed to comply the shortcomings under intimation to this department for further consideration in the matter. The occupancy of the building premises without valid Fire Safety Certificate is own risk and responsibility of the management committee.

Yours faithfully,

(ATUL GARG)
DIRECTOR

Ph 011-23414000

Copy to; -

1. The Joint Director (Bldg.), DDA, Vikas Sadan, INA, New Delhi.