

ONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 911

Dated: 14 / 11 /2025

To

The Principal Ashok Kumar Education Trust A-183/2, Khubram Park, Prem Nagar-I, Kirari Suleman Nagar, Delhi-110086.

Sub: - Regarding grant of fire safety certificate in r/o Ashok Kumar Education Trust located at A-183/2, Khubram Park, Prem Nagar-I, Kirari Suleman Nagar, Delhi-110086. Sir,

Please refer to your letter no- nil dated 10/10/2025 received in this department vide outdoor dairy no.7052 dated14/10/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 30/10/2025 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & first floors only. At the time of inspection Smt. Shilpa Dhaka (Owner) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

- 1. 02 nos. of staircases having width 90cm each are provided against the requirements of 1.50m each and both staircases continues from ground to terrace level are not provided.
- 2. Fire extinguishers are not provided.

3. Hose reel hose is not provided.

4. Terrace level fire pump capacity of 450lpm is not provided.

5. Terrace level fire water tank capacity of 10,000 Ltr is not provided.

6. Exit & floors signage's is not provided at strategic location in the school building.

7. Standby power supply is not provided.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school premises is at your own risk & responsibility.

Yours faithfully

(S.K. Dua)

Dy. Chief Fire Officer

Delhi Fire Service 9C Cy

Copy to:-

1. The Dy. Director of Education, Zone- XIII, District North West- B (II), Sector-9, Rohini, Delhi - 110085.