

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/2026/ 88

Dated : 29/01./2026

FIRE SAFETY CERTIFICATE

Certified that the M/s **Asia Yatri Niwas Guest House** located at **8409-10, Arya Nagar, Paharganj, New Delhi** building comprised of Ground Floor, plus Four Upper Floors, Ground Floor (Commercial having Shops), 1st Floor (03 Guest Rooms), 2nd (03 Guest Rooms), 3rd Floor (02 Guest Rooms & 01 Store) and 4th Floor – Not in use as per affidavit dated 22.01.2026, Total 08 Guest Rooms up to 3rd Floor only. The FSC was earlier granted by this department vide letter No. F6/DFS/MS/GH/2023/32 dated 01/02/2023 for 08 guest rooms up to 3rd Floor only. The guest house was re-inspected by the officer concerned of this department on 09/01/26 in the presence of **Sh. Raj Kumar, Owner** and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **“Residential building, (Sub Division – A-1): (Guest House) - 1st Floor (03 Guest Rooms), 2nd Floor (03 Guest Rooms) and 3rd Floor (02 Guest Rooms and 01 Store) Total 08 guest rooms up to third floor only** with effect from **29/01./2026** for period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010.

Issued ... 29/01/2026 at New Delhi by.



(Dr. S. K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

OIC BP

Copy To: -

1. The Commissioner, Municipal Corporation of Delhi, Civic Centre, Minto Road, New Delhi w.r.t Online application ID No. 2026010500080 dated 05/01/2026.
2. The Manager, M/s Asia Yatri Niwas Guest House, 8409-10, Arya Nagar, Paharganj, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. This FSC is valid for Guest House up to third floor only.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
4. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
5. The trained firefighting staff should be available round the clock.
6. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
7. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
10. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

1.	Name & address of the building: -	M/s Asia Yatri Niwas Guest House, 8409-10, Arya Nagar, Paharganj, New Delhi.		
2.	Type of occupancy: -	Residential, "Group-A" (Guest House) Ground + 04 Upper Floors Total 08 Guest Rooms Ground Floor – Shops 1 st Floor - 03 Guest Rooms 2 nd Floor - 03 Guest Rooms 3 rd Floor - 02 guest rooms + 01 no. Store Room 4 th Floor – Not in use as per affidavit dated 22.01.2026		
3.	Building Comprised of: -			
4.	Type of case: -	Renewal		
5.	Details of previous FSC: -	No. F6/DFS/MS/GH/2023/32 dated 01/02/2023		
6.	Fire safety directives No.: -	N/A		
7.	Date of inspection: -	09/01/2026		
8.	Name of the inspecting officer: -	Sh. Bhupender Prakash, ADO(CC)		
9.	Name & designation of officer From the building side: -	Sh. Raj Kumar, Owner		
10.	Year of construction: -	2001		
11.	Applicant's letter No: -	MCD Online ID. 2026010500080 dated 05/01/2026		
S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	• Road width	N/A	04 mtr. Approx.	N/A
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper floors	01 no.	01 no.	MR*
	• Basements	N/A	N/A	N/A
	b. Width of staircase			
	• Upper floors	0.80 mtr.	0.90 mtr.	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	01 no.	01 no.	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	N/A	N/A	N/A
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Natural/Exhaust Fan	MR
5.	Fire Extinguishers			
	• Total numbers	10 nos.	10 nos.	MR
	• Types	ABC & CO ₂	ABC & CO ₂	MR
	• ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	• Total number of each floor	N/A	Provided	N/A
	• Length of hose reel hose	N/A	30 mtr.	N/A
	• Nozzle diameter	N/A	05 mm	N/A

7.	Automatic Fire Detection & Alarming System.			
	• Type of detectors	CO	Provided	MR
	• Location of main panel	Ground Floor	Provided	MR
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooter's Location	At each floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	Ground level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Stand by pump output	N/A	N/A	N/A
	• Stand by pump head	N/A	N/A	N/A
	• Auto starting/Manual stopping	N/A	N/A	N/A
	• Pump House Access	N/A	N/A	N/A
	Terrace level			
	• Discharge of pump	N/A	450 LPM	N/A
	• Head of pump	N/A	30 mtr.	N/A
	• Power supply	N/A	Provided	N/A
	• Auto starting of pump	N/A	Provided	N/A
14.	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	Provided	N/A
	• Overhead tank capacity	N/A	5,000 ltr.	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Fireman's switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A


	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:	N/A	N/A	N/A

*PNF – Provided but Non-Functional, *MR – Meeting Requirement, *NMR – Not Meeting Requirement


The fire protection system provided in the building were randomly checked and found functional at the time of inspection.


In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no. No. F6/DFS/MS/GH/2023/32 dated 01/02/2023 up to third floor only under rule 35(6) of the Delhi Fire Service rules 2010. The last date for deemed approval is 03/02/2026.


Accordingly, DFA is prepared and put up for perusal and signature please.



Bhupender Prakash
ADO (CC)



DO (CD) 20/1/26



Dy. (F0) (ND 2)



Dy. (F0) (ND 2) 23/1/26



Principal Director


Dy. CFS to Issue



Dy. CFS to Issue



Dy. CFS to Issue 24/01/26


Dy. CFS to Issue 27/1/26


ADO/CC

As approved F-0 letter is put up for signature
please.


Bhupender Prakash
ADO (CC)


Dy. CPO (AD 2)


Dy. CPO (AD 2) 28/1/26


MS


MS