



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/GH/WZ/2025/ 231

Dated: 15/05/2025

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Ref: elt.mcdonline application no. 2025042607297

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s Astoria Guest House
located at 11A/28, WEA, Channa Market, Karol Bagh, New Delhi-05.

Sir,

With reference to the elt.mcdonline application no. 2025042607297 on the subject cited above, it is informed that the said guest house was inspected by the officer concerned of this department on 06.05.2025 in the presence of Mr. Avinash (Lessee) and following shortcoming were observed at the time of inspection.

1. Fire Check Door (FCD) not provided as per required Clause 7.31.x, UBBL 2016 (amendment dated 27.05.2019).
2. Hose reel found non functional.
3. Fire pump found non functional.
4. Fire tank not segregated (all tanks have domestic connections).

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service
07/5. Bps