

c/11

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2025/ 428

Dated: 21/05/2025

To

The Principal,
A.S.V.J. Primary School,
Ballimaran, Delhi - 110006.

Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o A.S.V.J. Primary School located at Ballimaran, Delhi - 110006.

Sir,

This has reference to your letter outdoor diary No. 276 dated 07.04.2025 on the subject cited above. In this connection, this is to inform you that the school building was inspected by officer concerned from this department on 15.05.2025 in the presence of Mrs. Shakuntla (Peon) and found that the school building is comprised of ground plus two upper floors. During the inspection, following shortcomings were observed:-

1. An additional fire escape staircase not less than 0.75 m wide not provided.
2. Fire extinguishers provided but not functional.
3. First aid hose reel of 30 m length with 5 mm shut-off-nozzle on each floor not provided.
4. Fire pump capacity of 450 LPM with 40 mtr. head not provided on terrace.
5. Overhead water storage tank capacity of 10,000 ltrs. not provided.
6. Exit signages are not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Tel: 011-23414000

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.