



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F.6/DFS/MS/School/2025/SZ/292

Dated: 05/06/2025

FIRE SAFETY CERTIFICATE

Certified that M/s **Atal Adarsh Vidyalaya** Sr. Sec. School located at Kidwai Nagar East, New Delhi-110023 (School ID: 2026073), comprised of Ground + 04 upper floors with two tier common basement, was issued FSC by this department vide letter No. F.6/DFS/MS/2016/SZ/574 dated 12/04/2016. The premises was re-inspected by the officer concerned of this department on dated 19/05/2025 in the presence of Sh. M.S. Verma (AE/NDMC) and observed that said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the premise/ building is fit for occupancy class "**Educational Group B**" (School) with effect from 05/06/2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 05/06/2025 at New Delhi by


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service


Copy to: -

1. The Assistant Engineer-II (Civil-Fire), Fire Department, New Delhi Municipal Council, Palika Kendra, New Delhi-110001
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

N-12

INSPECTION REPORT				
1.	Name & address of the building	Atal Adarsh Vidyalaya Sr. Sec. School, Kidwai Nagar East, New Delhi-110023 (School ID: 2026073)		
2.	Type of Occupancy	Educational (Group-B)		
3.	Building Comprised of	Ground + 4 upper floor (2 Tier Common Basement)		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F.6/DFS/MS/2016/SZ/574 dated 12/04/2016		
6.	Fire Safety directives letter No.	F.6/DFS/MS/BP/2013/308 dated 08/10/2013		
7.	Date of inspection	19/05/2025		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and designation of Officer from the building side	Sh. M.S. Verma (AE/NDMC)		
10.	Year of Construction	2016		
11.	Applicant's letter No.	A.E./D-586/Fire dated 29/04/2025 through Outdoor Diary No. 1198 dated 30/04/2025		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Sr. Sec. School within GPRA Colony, East Kidwai Nagar	12 mtr 06 mtr -NA-	MR MR -NA-
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper floors Basements 	03 Nos -NA-	03 Nos -NA-	MR -NA-
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper floors Basements 	1.5m (each) -NA-	1.5m (each) -NA-	MR -NA-
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	Required -NA-	Provided -NA-	MR -NA-
	d. No of continuous staircase to terrace	01 No	Provided	MR
	e. Width of Corridor	Required	1.5m	MR
	f. Door Size	1m	Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	Required Required Required -NA- -NA-	Provided Provided Provided -NA- -NA-	MR MR MR -NA- -NA-
4.	Smoke Managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	-NA- 12 ACPH	-NA- Natural ventilation	-NA- MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	30 Nos ABC/CO ₂ ISI Marked	Provided ABC, CO ₂ & WCO ₂ Provided	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	03 Nos 30m 5mm	02 Nos Provided Provided	MR (Old case) MR MR

19

7.	Automatic fire detection and alarming system			
	• Type of detector	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	-NA-	-NA-	-NA-
	• Upper Floor	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	• Size of riser/down- comer	100 mm	150 mm	MR
	• Number of hydrants per floor	2 Nos	Provided	MR
	• Hose Box	2 Nos	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	6nos near school	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements			
	• Ground Level	Common fire pump for entire complex		
	➤ Discharge of main pump	-NA-	2850 LPM x 2	-NA-
	➤ Head of main pump	-NA-	70m & 40m	-NA-
	➤ Number of main pumps	-NA-	2 + 2 for WC	-NA-
	➤ Jockey pump out put	-NA-	180 LPM	-NA-
	➤ Jockey pump head	-NA-	70m	-NA-
	➤ Standby Pump out put	-NA-	2850 LPM	-NA-
	➤ Standby Pump Head	-NA-	70m	-NA-
	➤ Auto Staring/Manual stopping	-NA-	Provided	-NA-
	➤ Pump House Access	-NA-	Provided	-NA-
	• Terrace level			
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water storage for firefighting			
	• Underground tank capacity	-NA-	2,00,000 Ltrs	-NA-
	➤ Draw of connection	-NA-	Provided	-NA-
	➤ Fire service inlet	-NA-	Provided	-NA-
	➤ Access to tank	-NA-	Provided	-NA-
	• Overhead Tank capacity	25,000 Ltr	25,000 Ltr	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-

N-19

19.	Fire Control Room			
	➤ Detector system panel	-NA-	-NA-	-NA-
	➤ Flow Switch Panel	-NA-	-NA-	-NA-
	➤ PA System Panel	-NA-	-NA-	-NA-
	➤ Battery backup	-NA-	-NA-	-NA-
	➤ Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	-NA-	-NA-	-NA-

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The shortcomings issued & communicated vide letter No. F.6/DFS/MS/School/2024/SZ/175 dated 08/04/2024 found complied.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/2016/SZ/574 dated 12/04/2016, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for perusal/approval & signature please.

[Signature]
22/05/25
Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO (SD) *[Signature]*
20/5/25

CFO (HQS) *[Signature]*
26/5/2025

Director
AD2/(SJ)

Sir, F.T letter is pending for forwarding

CFO (HQS) *[Signature]*
4/6/2025

MS cell

[Signature]
22/05/25