

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/Outer North/2026/ 336

Dated: 03/08/2026

To,

The Superintendent (Estate)
GNCTD, Social Welfare Department,
(Estate Branch), Block 2, Flat No. 11, Shankar Market,
Connaught Place, New Delhi - 110001.

Sub: Application for grant of fire safety certificate in r/o **Atal Asha Home located at MCD Campus, Lampur Road, Narela, Delhi - 110040.**


Sir,

This has a reference to letter No. F.54(514)/NursingCollegeBuilding/EC /DSW/23-24/5556-69 dated 17/07/2026 received through outward diary No. 3968 dated 17/07/2026 on the subject cited above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 27/07/2026 in the presence of Mr. Sanjay Kumar (Superintendent), Mr. Vivekanand (J.E. Civil), Mr. Omprakash Singh (A. E. Elect.) & Prince Kr. (J. E. Elect.). The following shortcomings are observed: -

1. Continuous staircase to terrace are not provided as per requirement.
2. Sealing of electrical shafts are not provided.
3. Smoke Management System at upper floor not provided.
4. First aid hose reels are provided but found nonfunctional.
5. Internal Hydrant Hose box not provided.
6. Stand by pump & Auto starting/Manual stopping at ground level provided but found nonfunctional.
7. Lift signages are not provided.

In view of the above, application for fire safety certificate is rejected. You are requested to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,


(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service