

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/NDZ/2025/ 746

Dated: 23/09/2025

To

The Principal,  
Atma Ram Senior Secondary School,  
Ajmeri Gate, Delhi - 110006.

Sub: Regarding issuance of Fire Safety Certificate (FSC) in r/o Atma Ram Senior Secondary School, Ajmeri Gate, Delhi - 110006.

Sir,

This has reference to letter outdoor diary No. 4404 dated 01.08.2025 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on dated 11.09.2025 and observed that the shortcomings intimated vide letter of even No.F6/DFS/MS/NDZ/School/2025/585 dated 11/07/2025 (copy enclosed) have not been complied yet.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

Encl: As above.

  
19/09/2025  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service  
o/c 8/19/19

**Copy to:-**

The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi.

C-19

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

No.F6/DFS/MS/NDZ/School/2025/ 585

Dated: 11 / 07 /2025

To

The Principal,  
Atma Ram S. D. Senior Secondary School,  
Ajmeri Gate, Delhi - 110006.

**Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o Atma Ram S. D. Senior Secondary School, Ajmeri Gate, Delhi - 110006..**

Sir,

This has reference to letter outdoor diary No. 2789 dated 17.06.2025 on the subject cited above. In this connection, this is to inform you that the school building was visited by officer concerned from this department on 05.06.2025 in the presence of Mr. Manish Sharma, PGT (Commerce) and observed that the school building is comprised of ground plus one upper floor (two blocks). During the inspection, following shortcoming was observed:-

1. The width <sup>of</sup> single staircase in each block is less than 1.50 meter therefore an additional fire escape staircase not less than 0.75 meter wide shall be provided for each block.
2. Fire extinguishers not maintained and not adequately provided.
3. Exit signages not provided.

In view of above shortcoming, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management.

Yours faithfully,

  
(Atul Garg)

Director

Delhi Fire Service

Tel: 011-23414000

**Copy to:-**

The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi.

o/c  
Dr. 11/7  
ost