



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F.6/DFS/MS/GH/NDZ/2026/

682

Dated: 16/07/2026

To,

Sh. Amit Pandey,
M/s The Aura Hotel and Banquet (Guest House),
1/5932 old No. 697 main Loni Road, Kabul Nagar, Shahdara,
Delhi-110032.

Subject: - Regarding renewal of Fire Safety Certificate in r/o M/s The Aura Hotel and Banquet (Guest House), 1/5932 old No. 697 main Loni Road, Kabul Nagar, Shahdara, Delhi-110032.

Sir,

This has a reference to MCD online application ID No. **2026060508229** dated 06/06/2026 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 27/06/2026 in presence of Sh. Amit Pandey, Owner. The building is comprised of basement, stilt, ground plus three upper floors but guest house is running first and second floor only. The following shortcomings were observed during the time of inspection.

1. Second staircase width 1.20 meter provided against the requirement of 1.50 meter width.
2. Fire check door not provided.
3. Width of corridor 1.20 meter provided against the requirement of 1.80 meter width.
4. Carbon mono oxide detector not provided.
5. Firemen's grounding switch & lift signage not provided.

In view of above shortcomings as noted at serial numbers 02, 07, 14 & 15, **the application for issuance Fire Safety Certificate is rejected.** The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Dr. S. K TOMAR)

o/c **DY. CHIEF FIRE OFFICER**

DELHI FIRE SERVICE

Copy to:-

1. The Commissioner, MCD, Dr. S.P. M. Civic Centre, Minto Road, New Delhi-110002
MCD ID No. **2026060508229**