



FIRE SAFETY CERTIFICATE

Certified that the AVB Adarsh Vidya Bhawan located at Plot No. 43, I. P. Extn. Near Bathla Apartment, Delhi - 110092, building comprised of ground plus three upper floors, owned /occupied by AVB Adarsh Vidya Bhawan, was issued FSC vide letter No. F6/DFS/MS/School/NDZ/2022/163 dated 11/02/2022. The School building was re-inspected by the officer concerned of this department on 07.01.2025 in presence of Mr. Pankaj Verma (Owner) & Mrs. Ritu Verma (Principal) found that the said school have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class (Group - B) "Educational Building" with effect from 15/01/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010. Subject to conditions printed below.

Issued on 15/01/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Principal, AVB Adarsh Vidya Bhawan located at Plot No. 43, I.P. Extn. Near Bathla Apartment, Delhi - 110092.
2. The Dy. Director of Education, D-Block, Anand Vihar, Delhi - 110092.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	AVB Adarsh Vidya Bhawan located at Plot No. 43, I.P. Extn. Near Bathla Apartment, Delhi-92		
2	Building is comprised of	Ground plus Three upper floors		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/NDZ/2022/163 dated 11/02/2022		
6	Fire safety directives letter no.	DFS Act 2007 and Rule -2010		
7	Date of inspection	07/01/2024		
8	Name of the inspecting officers	Yashwant Singh Meena ADO, Laxmi Nagar		
9	Name of the designation of officer from the building side	Mr. Pankaj Verma (Owner) & Mrs. Ritu Verma (Principal)		
10	Year of construction	2000		
11	Applicant's letter no.	Outdoor diary no. 10774 dated 26/12/2024		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Circular Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A Road width	6.0 mtrs.	15 mtrs.	MR
	B Gate width	4.50 mtrs	4.5 mtrs	MR
	C Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	03 nos.	03 nos.	MR
	b Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	1.5 mtr.	1.5 mtrs each	MR
	b Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	01 no.	01 no.	MR
	E Width of corridor	1.50 mtrs.	2.2 mtrs.	MR
	F Door size	1.0 mtr.	1.0 mtr.	MR
3	Compartmentation:			
	A Fire check door	N/A	N/A	N/A
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A

5.	Fire Extinguisher:			
	A	Total numbers	13 nos.	30 nos. /
	B	Types	CO ₂ & ABC	CO ₂ & ABC
	C	ISI marking	ISI Marked	Provided
6	First-Aid-Hose Reel:			
	A	Total numbers of each floor	02 no.	02 no.
	B	Length of hose reel hose	30 mtr.	30 mtr.
	C	Nozzle diameter	05 mm	05 mm
7	Automatic Fire Detection and Alarming System:			
	A	Type of detectors	N/A	N/A
	B	Location of main panel	N/A	N/A
	C	Location of repeater panel	N/A	N/A
	D	Alternate source of power	N/A	N/A
	E	Hooters	N/A	N/A
8	MOEFA:		N/A	Provided
9	Public Address System:			
10	Automatic Sprinkler System:			
	A	Basement	N/A	N/A
	B	Upper floor	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A
11	Internal Hydrants:			
	A	Size of riser/down-comer	100 mm	100 mm
	B	Number of hydrants per floor	02 nos	02 nos /
	C	Hose box	02 nos	02 nos
12	Yard Hydrants:			
	A	Total number of hydrants	N/A	N/A
	B	Hose box	N/A	N/A
13	Pumping Arrangements:			
1	Ground level			
	A	Discharge of main pump	N/A	N/A
	B	Head of main pump	N/A	N/A
	C	Number of main pumps	N/A	N/A
	D	Jockey pump out put	N/A	N/A
	E	Jockey pump head	N/A	N/A
	F	Standby pump out put	N/A	N/A
	G	Standby pump head	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A
	I	Pump house access	N/A	N/A
2	Terrace Level			
	A	Discharge of pump	450 LPM	450 LPM /
	B	Head of the pump	40 m	40 m
	C	Power supply	Required	Provided
	D	Auto starting of pump	Required	Provided

(u) A

✓

14	Captive Water Storage for Fire Fighting:				
	A	Underground tank capacity	N/A	10,000 ltrs	MR
	B	Draw-off connection	N/A	N/A	N/A
	C	Fire service inlet	N/A	N/A	N/A
	D	Access to tank	N/A	N/A	N/A
	E	Overhead tank capacity	5,000 liters.	5,000 liters.	MR
15	Exit Signage:		Required	Provided	MR
16	Provision of Lifts:				
	A	Pressurization of lift shaft	N/A	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A	N/A
	C	Communication in lift car	N/A	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A	N/A
	E	Lift signage	N/A	N/A	N/A
17	Standby Power Supply:				
18	Refuge Area:				
	A	Total area	N/A	N/A	N/A
	B	Location	N/A	N/A	N/A
19	Fire Control Room:				
	A	Detector system panel	N/A	N/A	N/A
	B	Flow switch panel	N/A	N/A	N/A
	C	PA system panel	N/A	N/A	N/A
	D	Battery backup	N/A	N/A	N/A
	E	Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:				

The fire protection system was randomly checked and tested and was found functional at the time of inspection.

Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no F6/DFS/MS/School/NDZ/2022/163 dated 11/02/2022, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended to be renewed.

Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO (Laxmi Nagar)

D.O/EAST

Dy. C.F.O. (NDZ)

C.F.O.

Director

P.T.O