



246
24/07/2025

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F6/DFS/MS/EH/2025/NDZ/ 279

Dated: 30/07/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Aveenashi Food and Beverage Pvt. Ltd. located at A-07 and 8, 1st floor, Kailash Park, Main Najafgarh Road, Delhi-110015 is running at First floor only owned/occupied by M/s Aveenashi Food and Beverage Pvt. Ltd. was issued FSC vide letter F.6/DFS/MS/EH/WZ/2021/302 dated 25/10/2021. The premises was re-inspected by the officer concerned of this department on dated 24/07/2025 in the presence of Sh. Ajay Kumar, Manger and observed that all the fire prevention and fire safety arrangements provided in the premises and found that the said premises found in good working condition. The premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit occupancy class "Assembly" Group D (First Floor only) with effect from 30/07/2025 and up to valid 31/03/2028 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010. Conditions Mentioned Below.

Issued on.....30/07/2025.....at New Delhi by.


30/07/2025
(Virendra Singh)
Chief Fire Officer

Copy to: -

1. The Owner/Occupier, M/s Aveenashi Food and Beverage Pvt. Ltd. located at A-07 and 8, 1st floor, Kailash Park, Main Najafgarh Road, Delhi-110015

MCD ID No. 2025062910723

Conditions for the validity of Fire Safety Certificate

1. FSC is valid for first floor only.
2. Basement shall be used as per building bye laws.
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
7. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : Aveenashi Food and Beverage Pvt. Ltd. A-07 and 8, 1st floor, Kailash Park, Main Najafgarh Road, Delhi-110015.
2. Type of Occupancy : Assembly (Eating House)
Building comprised of basement + ground + 03 upper floors but restaurant is running first floor only.
3. Type of Case : Renewal
4. Details of Previous NOC letter : F.6/DFS/MS/EH/WZ/2021/302 dt 25/10/2021
5. Fire Safety directive letter No : NBC Part IV
6. Date of Inspection : 24/07/2025
7. Name of the Inspecting officers : ADO (Shd.) Deepak Kumar
8. Name and designation of Officer from the building side : Sh. Ajay Kumar, Manger
9. Year of Construction : 2004
10. Applicant's letter No : 2025062910723, Dated- 29/06/2025

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	BBL/NBC Requirement /as per previous. Insp. report dated 25/10/2021	Provided at Site	Remarks MR/NMR
01	Access to Building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	09 mtr.	Provided	MR
		N/A	Directly accessible from the road	N/A
		N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> Upper floor Basement 	02 nos.	03 nos.	MR
		02 nos.	Provided	MR
	B. Width of Staircases			
	<ul style="list-style-type: none"> Upper floor Basement 	1.50 mtr & 01 mtr	02 mtr, 1.50 mtr & 1.25 mtr	MR
		N/A	2.20 mtr & 1.50 mtr	N/A
	c. Protection of Exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	02 nos. & 01 mtr	02 mtr, 1.50 mtr & 1.25 mtr	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> Basement Upper floor 	12 a/c per hours	N/A	N/A
		12 a/c per hours	Exhaust fan Provided	MR
05.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	06 nos.	Provided	MR
		ABC /CO ₂	Provided	MR
		Required	Provided	MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 nos.	Provided	MR
		30 mtr	Provided	MR
	• Length of hose reel hose	05 mm	Provided	MR
	• Nozzle diameter			
07	Automatic Fire Detection and Alarming System:-			
	• Type of detectors	Smok/Heat	Provided	MR
	• Location of main pane	Ground floor	Provided	MR
	• Location of repeater panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooter	Required	Provided	MR
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	Provided	N/A
	• upper floor	N/A	Provided	N/A
	• sprinkler above false ceiling	N/A	Provided	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01 no.	Provided	MR
	• Hose box	Required	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 lpm	Provided	MR
	• Head of the pump	40 mtr	Provided	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	Required	Provided	MR
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	10,000 ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR

N/14.

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:			

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule, the FSC issued vide letter no. F.6/DFS/MS/EH/WZ/2021/302 dt 25/10/2021 renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended..

Deepak
24/07/2025
Signature of the Inspecting Officer
Name : Deepak Kumar
Designation : ADO (Shd)

~~DCFO (WZ)~~

dy
25/7/2025

~~CFO~~

dhruv
26/7/2025

~~Principal Director~~

CFO to Secy.

CFO

28/07/25

dhruv
29/7/2025

~~ADO (Shd)~~

P.T.O