



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2025/SZ/College 89

Dated: 11 /08/2025

For Awadh Public Charitable Trust, M/s Awadh Bhawan, at FC-31, Sheikh Sarai-II, Press Enclave Road, New Delhi -110017

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Awadh Bhawan, at FC-31, Sheikh Sarai-II, Press Enclave Road, New Delhi -110017.

Sir,

This was reference to your letter no nil dated 16/06/2025 received through outdoor diary no 2784 dated 17/06/2025 on the subject cited above. In this concerned, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 15.07.2025 in the presence of Mr. Nitin Kumar to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

Fire check door not provided in basement. 1.

Smoke ventilation system not provided in the basement. 2.

First aid hose reel provided but non-functional. 3.

MOEFA provided but found non-functional.

Automatic Sprinkler system provided but found non-functional. 5.

Internal hydrant system provided but non functional. 6.

Fire fighting pumps 900 LPM provided but non-functional.

Underground tank capacity 1, 00,000 ltrs not provided.

9. Overhead tank capacity 10,000 ltrs provided against the required capacity of 20,000 ltrs.

10. Exit signage not provided at some places.

11. Open to sky court Yard at Ground floor have been covered and being used for Meeting hall. Hence there is a deviation in building plan.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(VIRENDRA SINGH) CHIEF FIRE OFFICER DELHI FIRE SERVICE