



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5
आज़ादी का
अमृत महोत्सव

Dated: 13/05/2026

No. F6/DFS/MS/BNQT/WZ/2026/465

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Center, New Delhi – 110002.

Subject: - Regarding grant of Fire Safety Certificate in r/o Ayraa Banquet (A unit of Shambhu Events LLP) located at Plot No. 69-70, Basement, GF, FF, SF, TF, Najafgarh Industrial Area, Delhi-110015.

Sir,

This has a reference to MCD application No. 2026041004783 dated 10/04/2026, on the subject cited above. In this connection, this is to inform you that the above mentioned premises was visited by the officers concerned of this department on dated 24/04/2026 in the presence of Mr. Lovleen Singhal (Owner) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observation:-

1. Fire Check door not provided at some locations.
2. Smoke management system not provided in basement.
3. Ground level pump of capacity 1620 LPM provided against the requirement of 2280 LPM.
4. Underground water tank of capacity 75,000 lit. provided against the requirement of 1,00,000 litr.
5. Exit signage not provided at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(S. K. Dua)

Chief Fire Officer
Delhi Fire Service

Copy to :

1. The Owner/Occupier, Ayraa Banquet (A unit of Shambhu Events LLP) located at Plot No. 69-70, Basement, GF, FF, SF, TF, Najafgarh Industrial Area, Delhi-110015.