



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75 C-75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/EH/SZ/2025/250

Dated:- 26/06/2025

FIRE SAFETY CERTIFICATE

Certified that M/s Azula, located at Ground Floor & Mezzanine Floor, 52-53, Community Centre, New Friends Colony, New Delhi-110025, comprised of basement, ground floor, mezzanine floor plus 03 upper floors only owned/occupied by Unit of Tigar Shark Hospitality and Concepts, was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/EH/2022/SZ/303 dated 02/11/2022. The said premise was re-inspected by the officer concerned of this department on 20/06/2025 in the presence of Sh. Dilkush (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy Class D "Assembly Building" (restaurant is running at ground & mezzanine floor only) with effect from 26/06/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 26/06/2025 at New Delhi by

(Atul Garg)
Director

Tel. No. 011-23414000

Copy to :-

1. The Commissioner, Municipal Corporation of Delhi, Civic Centre, Minto Road, New Delhi-110002 :- in r/o online application id. 2025052709205 dated 29/05/2025.
2. The Joint Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.
3. The Authorized Signatory, M/s Azula, Ground & Mezzanine floor, 52-53, Community Centre, New Friends Colony, New Delhi-110025.

Conditions for the validity of fire safety certificate :-

1. This FSC is valid for restaurant area at ground floor & mezzanine floor only.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/s. Azula (A Unit of Tiger Shark Hospitality and Concepts) located at GF & Mezz. Floor, 52-53, Community Centre, New Friends Colony, New Delhi-110065
2. Type of Occupancy : Assembly Building, "Group-D"
3. Type of Case : Renewal,
4. Details of previous NOC : F6/DFS/MS/EH 2022/SZ/303 dated 02/11/2022
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 20/06/2025
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer from the building side : Sh. Dilkhush (Manager)
9. Year of Construction : 2007
10. Applicant's letter no. : 2025052709205 dated 29/05/2025

The building is comprised of basement, ground, mezzanine floor plus 03 upper floors but restaurant is running at ground & mezzanine floor only.

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements as per earlier FSC issued dated 02/11/2022	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Required	06 m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 nos.	Provided	MR
	• Basements	02 nos.	Provided	MR
	b. Width of staircases			
	• Upper floors	1.25 m	1.08 m & 1.04 m	MR (Old Case)
	• Basements	1.25 m	1.08 m & 1.04 m	MR (Old Case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Required	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Exhaust Fan	MR
	• Upper floors	Required	Exhaust Fan	MR
5.	Fire Extinguishers			
	• Total numbers	Required	11 nos.	MR
	• Types	ABC & CO ₂	Provided	MR
	• ISI marking	ISI Marked	Provided	MR

21-23

6.	First – Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Required	Smoke type	MR
	• Location of Main Panel	Required	Ground Floor	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	Required	100 mm	MR
	• Ground Floor	Required	01 no.	MR
	• Sprinkler above false ceiling	Required	01 no.	MR
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm & 180 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for firefighting:			
	• Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000 ltrs.	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR


N-24




18.	Refuge Area			
	➤ Total area			
	➤ Location	NA	NA	NA
19.	Fire control room	NA	NA	NA
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no. F6/DFS/MS/EH 2022/SZ/303 dated 02/11/2022 renewal under rule 37 of the Delhi Fire Service Rule 2010, is recommended.

Accordingly ~~F.T.~~ is prepared & put up for approval please.


 Aman Kumar Lathar
 ADO (JWP)

DO (SP)

 CRO - on leave

 24/5/24


V. Pradeep
 22/6/25
