



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/WZ/School/2025/WZ/ 542

Dated:- 24/04/2025

FIRE SAFETY CERTIFICATE

Certified that the **B.S. Convent School**, Located at **Shiv Ram Park, Nangloi, Delhi-110041**, running on **Ground Floor only** in a building comprised of Ground + 02 Upper Floors, owned/occupied by **Sahid Ram Prasad Bismil Educational Society (Regd.)**, was issued Fire Safety Certificate by this department vide letter no. **F6/DFS/MS/School/WZ/2015/1521 dated 21/08/2015**. The said premise was re-inspected by the officer concerned of this department on 15/04/2025 in the presence of Sh. Parashant Singh (Manager) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E. Cr. No. 3298-3398 dated 01/03/2011 and that the school building is fit for occupancy class **"Educational Building" Group B** (Ground Floor only) with effect from 24/04/2025 for a period of **three years**, subject to compliance of the conditions, printed below.

Issued on 24/04/2025 at New Delhi by

(Atul Garg)
Director

Tel No. 011-23414000

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, B.S. Convent School, Shiv Ram Park, Nangloi, Delhi-110041.

Conditions for the validity of fire safety certificate:-

1. This FSC is valid for ground only.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
10. The school management has given an undertaking that the two floors (first and second) are not in use due to shortage of students and they assure that same floor shall not be used by any means by school. If they found using the same their fire safety certificate may be treated as null and void.

INSPECTION REPORT p

1. Name and address of the building: **B. S. Convent School**, located at **Shiv Ram Park, Nangloi, Delhi-110041**
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/WZ/2015/1521 dated 21/08/2015
5. Fire Safety directives Letter No. : D.O.E. Cr. No. 3298-3398 dated 01/03/2011
6. Date of inspection : 15/04/2025
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Sh. Parshant Singh (Manager)
9. Year of Construction : 2003
10. Applicant's letter No. : BSCS/04/2025 dated 03/04/2025

The building is comprised of ground + 02 upper floors but school is running at ground floor only.

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements as per D.O.E. Cr. No. 3298-3398 dated 01/03/2011		Provided at site	Remarks MR/NMR
1.	Access of building				
	• Road width	Accessible	Provided		MR
	• Gate width	Accessible	Provided		MR
	• Width of internal road	NA	NA		NA
2.	Number, width, Type & Arrangements of exits				
	a. Number of staircases				
	• Upper floors	NA	NA		NA
	• Basements	NA	NA		NA
	b. Width of staircases				
	• Upper floors	NA	NA		NA
	• Basements	NA	NA		NA
	c. Protection of exits				
	• Fire check door	NA	NA		NA
	• Pressurization	NA	NA		NA
	d. No of continuous staircase to terrace	NA	NA		NA
	e. Width Of Corridor	NA	NA		NA
	f. Door Size	1.0 m	Provided		MR
3.	Compartmentation				
	• Fire check door	NA	NA		NA
	• Sealing of electrical shafts	NA	NA		NA
	• Fire Rating of shaft door	NA	NA		NA
	• Water Curtain	NA	NA		NA
	• Fire Dampers	NA	NA		NA
4.	Smoke managements System				
	• Basements	NA	NA		NA
	• Upper floors	NA	NA		NA

Qm.

5.	Fire Extinguishers			
	• Total numbers	02 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First – Aid Hose Reel			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA

	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area	NA	NA	NA
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Note:- In the reply of the earlier shortcoming issued vide letter no. F6/DFS/MS/School/2018/5185 dated 28/12/2018, the school management has given an undertaking that the two floors (first and second) are not in use due to shortage of students and I assure you same floors shall not be used by any means by school. If we found using the same our fire safety certificate may be treated as null and void.

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as per D.O.E. Circular no. 3298-3398 dated 01/03/2011, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/WZ/2015/1521 dated 21/08/2015 is recommended.

Accordingly DFA is prepared for approval & signature please.

Aman Kumar Lathar
ADO (JWP)

DCFO/6SO-162D...
Dated...17/04/25...

CFD
21/4/2015
Director

Amrinder

Sir, R.T. letter is put-up for your signature pl.

Director

Aman Kumar Lathar
23/4/25
ADO (JWP)