

 GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/GH/2026/NZ/ 63)

Dated: 07/07/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
S.P.M. Civic Centre, J.L. Nehru Marg
New Delhi 110002.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s Baba Guest House Located at A-17, Kewal Park Extension, Azadpur, Delhi-33.

Sir,

This has reference to online application received through MCD portal vide ID- 2026060508219 on the subject cited above. In this connection, it is to inform you that the above said residential building was re-inspected by officer concerned of this department on 24/06/2026 to see the compliance of requisite fire safety measures. Mr. Deepak was present at the time of inspection. Following shortcoming were observed at the time of inspection.

1. Overhead tank of 2,000 ltrs capacity found provided against the required capacity of 5,000 ltrs.
2. The extra rooms at both the floors have to be sealed with brick wall.

In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully



(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. M/s Baba Guest House Located at A-17, Kewal Park Extension, Azadpur, Delhi-33.
2. MCD Portal ID No. 2026060508219.