



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/School/2025/SZ/ 784

Dated: 23/10/2025

To,

The Principal,
Babu Khem Chand Advocate Memorial Public School
Street No. 56, II nd 60 Feet Road, Subzi, Molarbandh Extn.,
Badarpur, New Delhi – 110044.

Subject: - Regarding issuance of Fire Safety Certificate in r/o Babu Khem Chand Advocate Memorial Public School located at Street No. 56, II nd 60 Feet Road, Subzi, Molarbandh Extn., Badarpur, New Delhi – 110044.

Sir,

Please refer to your outdoor dairy No. 5536 dated 02/09/2025 on the subject cited above. In this connection, it is to inform you that the site was visited by officer concerned of this department on dated 06/10/2025 in the presence of Mr. Devender Choudhary (Manager) and observed that the shortcoming has still not complied with as issued by this department vide letter no. F6/DFS/MS/School/SZ/2022/667 dated 01/11/2022 (copy overleaf).

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully,

Enclose as above


24/10/25

(A.K. Malik)

Dy. Chief Fire Officer

O/c Delhi Fire Service

Copy to: -

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

75
गणराज्य
अग्नि महोदय



No. F6/I

No.F6/DFS/MS/School/SZ/2022/667

Dated: 01/11/22

To

The Principal,
Babu Khem Chand Advocate Memorial Public School,
Street no. 56, 60ft Road, Subzi Mandi,
Molarband Extension, Badarpur, New Delhi-44.

Sub:- Regarding renewal of Fire Safety Certificate in respect of Babu Khem Chand Advocate Memorial Public School located at Street no. 56, 60ft Road, Subzi Mandi Molarband Extension, Badarpur, New Delhi-44.

Sir,

This has reference to your letter no. nil dated 24.08.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 14.10.2022 in the presence of Sh. Himanshu and it was observed that the school building is comprised of Basement (Sealed) + Ground + 2 upper floors. During the inspection following shortcomings was observed:-

1. Hose reel found non functional.
2. Fire pump found non functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Sunil Chawdhary)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.