



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आजादी का
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2025/ 459

Dated: 26/05/2025

To,

Babyland Public School,
B-99, Pandit Jai Ram Sharma Marg,
Shakarpur, Delhi-110092.

**Subject: - Regarding grant of Fire Safety Certificate in r/o Babyland Public School located at B-99,
Pandit Jai Ram Sharma Marg, Shakarpur, Delhi-110092.**

Sir,

This has a reference to your Outdoor diary No. 431 dated 09/04/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 14/05/2025 in the presence of Mrs. Nupur Aggarwal (Incharge) and observed that building comprised of ground plus one upper floor.

Following shortcomings were observed during time of inspection:

1. Staircase width of 0.90 meter provided against the requirement of 1.5 meters.
2. Fire extinguisher found removed.
3. First-Aid-Hose Reel found removed.
4. Fire pump of 220 LPM found removed.
5. Overhead water storage tank of capacity 1000 liters found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, MCD Civic Centre, Jawahar Lal Nehru Marg, New Delhi-110002.