



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/2025/WZ/ 163



Dated: 04/04/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **Delhi Metro Rail Corporation Ltd** at **Badli Enclave Metro Station** of **Line 2 Ext. Delhi**, comprised of **Ground Level + Concourse Level + Platform Level** owned/occupied by **Delhi Metro Rail Corporation Ltd** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/2022/WZ/139** dated **31.03.2022**. The premises was re-inspected by the officer concerned of this department on **27.03.2025** in the presence of **Mr. Pushkar (AM/Fire)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **"D" Assembly Building less than 15 mtr** with effect from 04/04/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 04/04/2025 at New Delhi by

(Atul Garg)  
DIRECTOR  
Ph; 011-23414000  
OK  
my

Copy to :-

1. Mr. Rajesh Agrawal, (GM/E&M) Metro Bhawan, 13, Fire Brigade Lane, Barakhamba Road, New Delhi-110001.
2. Mr. Pushkar (Fire Inspector) Delhi Metro Rail Corporation Ltd at Badli Enclave Metro Station of Line 2 Ext. Delhi,

**Conditions for the validity of fire safety certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner/ occupier shall submit a declaration **every year** in **Form 'K'** [sub rule (2) of Rule 38] provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [http://delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction (Clause 2.9.2 of UBBL-2016) or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of Rule 37] along with a copy of this Certificate, **six months** prior to its expiry."



## INSPECTION REPORT

1. Name & address of the building	Delhi Metro Rail Corporation Ltd at Badli Enclave Metro Station of Line 2 Ext. Delhi			
2. Type of Occupancy	Assembly			
3. Type of Case	Renewal (Ground Level + Concourse Level + Platform Level)			
4. Details of Previous NOC	F.6/DFS/MS/2022/WZ/139 dated 31.03.2022.			
5. Fire Safety directives letter No	F.6/DFS/MS/BP/2013/259 dated 30.08.2013.			
6. Date of inspection	27.03.2025			
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)			
8. Name and designation of officers From the building side	Mr. Pushkar (AM/Fire)			
9. Year of Construction	2013			
10. Applicant's letter No.	OD No.12831 dated 24.02.2025.			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	5m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			
	• Upper Floors	06nos. Concourse to platform 02nos. ground to Concourse	Provided	MR
	• Basements	-NA-	-NA-	-NA-
	<b>b. Width of staircases</b>			
	• Upper Floor	3.8 x 2nos. 2.05 x 2nos. 3.85 x 1 & 1.47 x 1 for future Extn.	Provided Provided Provided	MR
	• Basements	-NA-	-NA-	-NA-
	<b>c. Protection of exits</b>			
	• Fire check door	Required	Provided	MR
	• Pressurization	-NA-	-NA-	-NA-
	<b>d. No. of continuous staircases to terrace</b>	02nos.	Provided	MR
	<b>e. Width of Corridor</b>	-NA-	-NA-	-NA-
	<b>f. Door Size</b>	-NA-	-NA-	-NA-
3.	<b>Compartmentation</b>			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	<b>Smoke Management System</b>			
	a) Basements	-NA-	-NA-	-NA-
	b) Upper floors	12 a/c per hour	Natural ventilated	MR
5.	<b>Fire Extinguishers</b>			
	• Total numbers	20nos.	Provided	MR
	• Types	ABC/CO2	ABC/CO2	MR
	• IS marking	ISI marked	Yes	MR
6.	<b>First-Aid Hose Reels</b>			

	• Total numbers on each floor	06 on each platform ¾ on Concourse/Platform	06 on each platform ¾ on Concourse/ Platform	MR
	• Length of hose reel hose	45mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
<b>7.</b>	<b>Automatic fire detection and alarming system</b>			
	a) Type of detectors	Smoke	Provided	MR
	b) Location of Main Panel	Required	Provided	MR
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	Required	Provided	MR
	e) Hooters' Location	Required	Provided	MR
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	• Basement	-NA-	-NA-	-NA-
	• Ground & Upper Floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
<b>11.</b>	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	150mm	Provided	MR
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box	Required	Provided	MR
<b>12.</b>	<b>Yard Hydrants</b>			
	• Total number of hydrants	02nos.	Provided	MR
	• Hose Box	Required	Provided	MR
<b>13.</b>	<b>Pumping Arrangements</b>			
	• Ground Level			
	➤ Discharge of main Pump	1800lpm	1800lpm	MR
	➤ Head of Main pump	70m	70m	MR
	➤ Number of main pumps	01	01	MR
	➤ Jockey Pump out put	180lpm	180lpm	MR
	➤ Jockey pump head	70m	70m	MR
	➤ Standby Pump out put	1800lpm	1800lpm	MR
	➤ Standby Pump Head	70m	70m	MR
	➤ Auto Starting/Manual Stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	Terrace level			
	➤ Discharge of pump	-NA-	-NA-	-NA-
	➤ Head of the pump	-NA-	-NA-	-NA-
	➤ Power Supply	-NA-	-NA-	-NA-
	➤ Auto Starting of pump	-NA-	-NA-	-NA-
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	50,000ltr	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000ltr	Provided	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	• Pressurization of Lift lobby	-NA-	-NA-	-NA-



	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.	Required	Provided	MR
	➤ Total Area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-
19.	Fire Control Room	-NA-	-NA-	-NA-
	• Detector System Panel	Required	Provided	MR
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F.6/DFS/MS/2022/WZ/139** dated **31.03.2022** is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Signature of the Inspecting Officer  
 Name Ajay Kumar Sharma  
 Designation ADO(Rohini)

D.B Mukherjee  
 DO (NW)

*[Signature]*  
 28/03/2025

*[Signature]*  
 Dy CFA (WZ)

*[Signature]*  
 28/3

1092-NW...  
 28/03/25...

*[Signature]*  
 CFA / 14/1/2025

*[Signature]*  
 Director

Director

At letter is put up for  
 kind perusal & sign for

*[Signature]*  
 24/1/25