

DFA
C/47

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/2025/ School/ 533

Dated: 24/04/2025

FIRE SAFETY CERTIFICATE

Certified that the **Bajaj Public School** located at Street no.-04, Prem Nagar, New Delhi-110008, comprises of Basement, **Ground + 02 Upper floors**, was earlier granted FSC by this department vide letter No. F6/DFS/MS/School/SZ/2022/312 dated 25/03/2022. Now, the premises was re-inspected by the officer concerned of this department on 15/04/25 in the presence of the Ms. Shrey Bajaj and found that school has deemed complied with the fire prevention and fire safety requirements in accordance with circular of Director of education dated 17/01/2005 and the premises is fit for occupancy of class **Group B "Educational Building" Sub-Div. B-I** with effect from 24/04/2025..... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on 24/04/2025..... at New Delhi by.

(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to:-

1. The Commissioner , MCD , Civic Centre , New Delhi : to ensure the occupancy deviations if any
2. Director of Education, Govt. of NCT, Delhi.
3. The Manager , Bajaj Public School located at Street no.-04, Prem Nagar, New Delhi-110008,

Conditions for the validity of fire safety certificate

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the fire safety arrangements provided there in shall be maintained in good working condition at all time.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
6. Basement shall be used for storage as per BBL Concerned.
7. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
9. Any flammable material for interior decoration shall strictly prohibited.

INSPECTION REPORT

1. Name & address of the building:- Bajaj Public School located at Street no.-4, Prem Nagar, New Delhi-110008, Educational Group B-I, B+Gr. + 02 Upper floors, renewal
2. Type of occupancy:- F6/DFS/MS/School/SZ/2022/312 dated 25/03/2022
3. Type of case:- N/A
4. Details of previous FSC:- 10/04/2025.
5. Fire safety directives No.- Sh. Ravinder Singh (ADO/CC)
6. Date of inspection:- Mr. Shrey Bajaj
7. Name of the inspecting officer:- 1980
8. Name & designation of officer From the building side:- letter no. BPS/DFS/A/25 dated 20.01.2025.
9. Year of construction:-
10. Applicant's letter No:-

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement as per FSC dated 02.04.2019	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mts	provided	MR
	2) Gate width	4.5 m	provided	MR
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02	02	MR
	2. Basements	02	02	N/A
	B. Width of staircase			
	1. Upper floors	01 of 1.5 mts, or 02 of any length	1.15, 1.10 mts	MR
	2. Basements	01 of 1.5 mts, or 02 of any length	1.15, 0.80 mts	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	1.5 m	Provided	MR
	F. Door size	1.0 mt.	1.18 mts	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	12 a/c per hour	Provided	MR

	2) Upper floors	12 a/c per hour	Natural Vent.	MR
5.	Fire Extinguishers			
	1) Total numbers	12 Nos.	Provided	MR
	2) Types	ABC & CO2	ABC, CO2 & W.CO2	MR
	3) ISI marking	ISI marked	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01 nos.	01 nos.	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	provided	MR
	b) Head of pump	30 mtr.	40 m each	MR
	c) Power supply	Required	Provided	MR

N (13)

	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 ltr.	10,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued vide letter No. F6/DFS/MS/School/SZ/2022/312 dated 25/03/2022, under rule 35(6) of the Delhi Fire Service Rules 2010. Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer

Name :- Ravinder Singh
Designation :- ADO (CC)

[Signature]
17/4/25

[Signature]
21/4/2025
Director

[Signature]