C-39

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/WZ/2026/ 931 Dated: - 13/11/2026

To,

The Principal,
Bal Bharti Nursery School,
Pocket-7, Sector-25, Rohini, Delhi-110085.

Sub.: - Regarding issuance of Fire Safety Certificate in respect Bal Bharti Nursery School, located at Pocket-7, Sector-25, Rohini, Delhi-110085.

Sir,

This has reference to your email & Form 'I' dated 18/08/2026 on the subject cited above. In this connection, it is to inform you that the said building was re-inspected by the officer concerned of this department on 07/09/2026 in the presence of Ms. Anjana (Head Mistress). During inspection, it was observed that the above said building is comprised of ground + 02 upper floors. After inspection, the following shortcoming were observed: -

1. The lift has not yet been installed as proposed in the guidelines issued by this Department vide Letter No. F6/DFS/MS/School/2022/BP/307 dated 28/06/2022. Accordingly, the opening of the lift shaft is required to be sealed at every floor level until the lift is installed by the owner/occupier.

In view of the above shortcomings, the application for issuance of Fire Safety Certificate cannot be considered at this stage & **rejected.** And also, the Fire Safety Certificate issued by this department vide letter No. **F6/DFS/MS/2025/School/WZ/514 dated 22/04/2025** stands suspended until the shortcomings are not rectified by the owner/occupier mentioned as above. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

13/11/26

(A.K. Malik)
Chief Fire Service
Delhi Fire Service

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.