



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

7/11/25  
आज़ादी का  
अमृत महोत्सव


No.F6/DFS/MS/School/NDZ/2025/1284

Dated: 04/11/2025

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Bal Bhawan Public Sr. Sec. School located at F- Block, Laxmi Nagar, Delhi-91, comprised of Ground + 03 upper floors was granted Fire Safety Certificate (FSC) by this department vide letter no. F.6/DFS/MS/2022/NDZ/School/1197 dated 31.10.2022. The school building was re-inspected by Assistant Divisional Officer (L.N) from this department on 17.10.2025 in the presence of Sh. Deepesh Gupta (Principal) and found that the building/premises has deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of Delhi Fire Service Rules, 2010 and the building (Ground + 03 upper floors) is fit for occupancy of Group B "Educational Building" with effect from ...04/11/2025..... for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on...04/11/2025.....at New Delhi by

  
(Dr. S.K. Tomar)

Dy. Chief Fire Officer (NDZ)  
Delhi Fire Service

**Copy to:-**

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, M/s Bal Bhawan Public Sr. Sec. School located at F- Block, Laxmi Nagar, Delhi-91.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub Rule (1) of Rule 37] along with a copy of this certificate, six months prior to its expiry.



## INSPECTION REPORT

1	Name & address of the building	M/s Bal Bhawan Public Sr. Sec. School located at F-Block, Laxmi Nagar, Delhi-91.		
2	Building is comprised of	Ground + 03 upper floors		
3	Type of occupancy	Educational 'Group B' (School)		
4	Type of case	Renewal		
5	Details of previous FSC	F.6/DFS/MS/2022/NDZ/School/1197 dated 31.10.2022		
6	Fire safety direction letter no.	NBC Part-IV		
7	Date of inspection	17.10.2025		
8	Name of the inspecting officers	Rajesh Kumar Shukla, ADO (L.N)		
9	Name of the designation of officer from the building side	Sh. Deepesh Gupta (Principal)		
10	Year of construction	2000		
11	Applicant's letter no.	Outdoor diary no. 6734 dated 06.10.2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement as per Rules 35 (6)	Provided at site	Remarks MR/NMR
1	<b>Access to Building:</b>			
	A Road width	6.0 m	6.0 m	MR
	B Gate width	4.5 m	4.5 m	MR
	C Width of internal road	NA	NA	NA
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
	A Number of staircases	02 nos.	04 nos.	MR
	a Upper floor	NA	NA	NA
	b Basement	NA	NA	NA
	B Width of staircases	1 staircase of 1.5 mtrs or if main staircase width is < 1.5 mtrs an additional staircase of 0.75 mtrs width is required.	1.02 m, 1.02, 1.04 m & 1.50 m	MR (Old accepted)
	a Upper floor	NA	NA	NA
	b Basement	NA	NA	NA
	C Protection of exits	NA	NA	NA
	a Fire check door	NA	NA	NA
	b Pressurization	NA	NA	MR
	D No. of continuous staircases to terrace	02 nos.	03 nos.	MR
	E Width of corridor	1.50 m	1.80 m	MR
	F Door size	1.0 M for class room	1.0 M for class room	MR
3	<b>Compartmentation:</b>			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	NA	NA	NA
	C Fire rating of shaft door	NA	NA	NA
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
4	<b>Smoke Management System:</b>			
	A Basement	NA	NA	NA
	B Upper floor	NA	NA	NA
5.	<b>Fire Extinguisher:</b>			
	A Total numbers	16 nos.	21 nos.	MR
	B Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	C ISI marking	ISI Marked	Provided	MR
6	<b>First-Aid-Hose Reel:</b>			
	A Total numbers of each floor	02 nos.	02 nos.	MR
	B Length of hose reel hose	30 m	30 m	MR
	C Nozzle diameter	05 mm	05mm	MR
7	<b>Automatic Fire Detection and Alarming System:</b>			
	A Type of detectors	NA	NA	NA
	B Location of main panel	NA	NA	NA
	C Location of repeater panel	NA	NA	NA
	D Alternate source of power	NA	NA	NA
	E Hooters	NA	NA	NA

8	MOEFA:		NA	NA	NA
9	Public Address System:		NA	NA	NA
10	Automatic Sprinkler System:				
	A	Basement	NA	NA	NA
	B	Upper floor	NA	NA	NA
	C	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:				
	A	Size of riser/down-comer	100 mm	100 mm	MR
	B	Number of hydrants per floor	02 nos.	02 nos.	MR
	C	Hose box	02 nos.	02 nos.	MR
12	Yard Hydrants:				
	A	Total number of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping Arrangements:				
A	Ground level				
	a)	Discharge of main pump	NA	NA	NA
	b)	Head of main pump	NA	NA	NA
	c)	Number of main pumps	NA	NA	NA
	d)	Jockey pump out put	NA	NA	NA
	e)	Jockey pump head	NA	NA	NA
	f)	Standby pump out put	NA	NA	NA
	g)	Standby pump head	NA	NA	NA
	h)	Auto starting /manual stopping	NA	NA	NA
	i)	Pump house access	NA	NA	NA
B	Terrace Level				
	a)	Discharge of pump	450 & 220 LPM	450 & 220 LPM	MR
	b)	Head of the pump	40 mtrs	40 mtrs	MR
	c)	Power supply	Required	Provided	MR
	d)	Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting:				
	A	Underground tank capacity	NA	NA	NA
	B	Draw-off connection	NA	NA	NA
	C	Fire service inlet	Required	Provided	MR
	D	Access to tank	Required	Provided	MR
	E	Overhead tank capacity	10,000 liters	10,000 liters	MR
15	Exit Signage:		Required	Provided	MR
16	Provision of Lifts:				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Firemen's grounding switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
17	Standby Power Supply:		NA	NA	NA
18	Refuge Area:				
	A	Total area	NA	NA	NA
	B	Location	NA	NA	NA
19	Fire Control Room:				
	A	Detector system panel	NA	NA	NA
	B	Flow switch panel	NA	NA	NA
	C	PA system panel	NA	NA	NA
	D	Battery backup	NA	NA	NA
	E	Building floor plans	NA	NA	NA



20/25

M/s Bal Bhawan Public Sr. Sec. School located at F- Block, Laxmi Nagar, Delhi-91.

20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA
----	--	----	----

**LEGENDS- Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).**

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required as required under the Rules, the FSC issued vide letter no. F.6/DFS/MS/2022/NDZ/School/1197 dated 31.10.2022 is recommended to be renewed.

Signature of the Inspecting Officer  
Name Rajesh Kumar Shukla  
Designation ADO (L.N)

DO (East)

*[Signature]* 21/10/25

Dy. CPO (NDZ)

*[Signature]* 22/10/25

~~Principal Director~~

Dy. CPO put up fair copy

~~Dy. CPO (NDZ)~~

*[Signature]* 22/10/25

Pl. put up as directed

ADO (L.N)

FI is put up for signatures pl

~~Dy. CPO (NDZ)~~

*[Signature]* 28/10/25

Fair copy is put up for approval please.

*[Signature]* 28/10/25

~~Principal Director~~

Dy. CPO to *[Signature]*

~~Dy. CPO (NDZ)~~

*[Signature]* 31/11/25

F.A. pl.

ADO (L.N)

FI is put up for signatures pl

~~Dy. CPO (NDZ)~~

*[Signature]* 31/11/25

*[Signature]* 03/11/25