



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001



Dated 02/05/2025

No. F.6/DFS/MS/School/2025/NDZ/ 323

To,

The Manager,
Bal Jyoti Public School.
X-2/3C, Gali No. 5, Brahmpuri,
Delhi-110053..

Sub:- Regarding Issuance of Fire Safety Certificate r/o Bal Jyoti Public School located at X-2/3C, Gali No. 5, Brahmpuri Delhi-110053.

Sir,

With reference to your letter no.nil dated 17/02/2025 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection on dated 22/04/2025 of the above mentioned School from fire safety point of view in presence of the Sh. Satyaprakash Vajpayee, Manager of the school. The building comprised of ground plus one upper floor. Following shortcomings were observed during the time of inspection.

1. Second staircase of width 01 meter found removed.
2. First Aid Hose reels provided but not functional.
3. A terrace pump 220 lpm head 40 meters found removed.
4. An over head capacity 2.500 liters not provided.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to rectify the above mentioned shortcomings under intimation to this office for further course of action.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

The Dy. Director of Education
B-Block, Yamuna Vihar, Delhi-110053