



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/11/25 CM
आपदादीक
अमृत महोत्सव

No.F6/DFS/MS/School/NDZ/2025/801

Dated: 11/11/2025

To

The Principal,
Bal Niketan Public School,
PP8, J- Extension, Laxmi Nagar,
Delhi-92.

Sub:- Regarding issuance of Fire Safety Certificate in r/o Bal Niketan Public School located at PP8, J- Extension, Laxmi Nagar, Delhi-92.

Sir,

With reference to the letter bearing outdoor diary no. 6172 dated 19.09.2025 on the subject cited above, it is informed that the school was inspected by officer concerned from this department on 01.11.2025 in the presence of Sh. Mahender (Caretaker) and it was observed that the school building is comprised of Ground + 01 upper floor & 02 rooms on terrace used as a residence. During the inspection following shortcomings were observed:-

1. The school is not accessible to fire engines as approach road width is less than 6.0 meters.
2. Main Staircase of width 1.5 meters has not been provided.
3. First aid hose reels have not been provided at each floor.
4. Terrace Fire pump of 450 LPM with head 40 m has not been provided.
5. Overhand tank capacity of 10,000 liters for firefighting has not been provided.
6. Exit signage has not been provided.
7. Two nos. of staircases continuous to terrace has not been provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Dr. S. K. Tomar)

Dy. Chief Fire Officer (NDZ)

O/C

Copy to:-

1. The Dy. Director of Education, MCD, 419, Udyog Sadan Patparganj Industrial Area, Delhi-92.