

41

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6./DFS/MS/BP/2025/ 453

Dated: 10/09/2025

To,

The Authorized Signatory
Balaji Neuro Maternity and Child Care Centre,
232, Block – 7, Sunder Vihar,
New Delhi – 110087.

Sub: - Regarding issuance of fire safety directives in R/o Balaji Neuro Maternity and Child Care Centre, Plot No. 232, Block No. 7, Sunder Vihar, New Delhi – 110087.

Sir,

Please refer your letter Ref. No. BNMCC/2025/56/FIRE/I dated 08/08/2025 vide diary No. 4754 dated 11/08/2025 on the subject cited above. In this connection it is to inform you that the as built building plans have been scrutinized from fire/life safety point of view and observed that this is a proposal of Nursing Home building i.e. Bali Ji Neuro Maternity and Child Care Centre, 232, Block – 7, Sundar Vihar, New Delhi – 110087.

Following shortcomings are observed:

1. Exit doorways are not opening as per clause 7.12.5 of UBBL- 2016.
2. The Underground water Pumps 01 electric pump and 01 diesel pump of 1620 LPM capacity and 01 electric Jockey pump of 180 LPM are not proposed as per NBC Part IV- 2016.

Accordingly, the case is hereby rejected.

Yours faithfully,


(Virendra Singh)

Chief Fire Officer

Ph. No. 011- 23414333

Copy to: -

The MS, Nursing Home Cell
Directorate General of Health Services,
Govt. of NCT of Delhi, S-1, 3rd Floor,
School Block, Shakarpur, Delhi – 110092.