



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

C-3



No F 6/DFS/MS/2025/School/WZ/ 678

Dated: 22 / 08 / 2025

To,

The Principal,
Baldeep Public School,
L-181-182, Vijay Vihar, Phase-II,
Rohini, Delhi-110085.

Sub: Issue of FSC in r/o Baldeep Public School, located L-181-182, Vijay Vihar, Phase-II, Rohini, Delhi-110085.

Sir,

Kindly refer to online mail dated 26.06.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **05.08.2025**, in presence of **Mrs. Reenu (In-charge)** to ascertain the availability and operability of the fire prevention and fire safety measures. The following **shortcomings** were observed:

1. Accessible road on which building abuts is less than 6mtr.
2. The width of staircase is 1.09m to 0.90m against the required two staircase width of 1.5 mtr each & one staircase found ground to 1st floor.
3. First Aid hose reel not provided.
4. Terrace Fire pump with capacity of 450 LPM not provided.
5. Over Head water captive tank of 10,000 ltrs not provided.
6. The required exit signage are not provided.
7. Copy of approved/ as built plans & proof of year of construction school building may kindly be provided

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to: -

The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54