

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2025/SZ/ 363

Dated 03/09/2025

To

The Commissioner,  
Municipal Corporation of Delhi,  
E-1, 9th Floor, Dr. SPM Civic Centre,  
Minto Road, New Delhi-110002

**Sub:** - Regarding issuance of fire safety certificate in r/o M/s Bamisaal The Food Court (A Unit of JMD Hotels Pvt Ltd) running at Lower Ground Floor, at G-6, Janak Palace, District Centre, Janakpuri, New Delhi 110058.

Sir,

This has reference with **MCD Portal ID 2025072911990 dated 29/07/2025** on the subject cited above. In this connection, this is to inform you that the above-mentioned premise was visited by the officer concerned of this department on 20.08.2025 in the presence of Mr. Sujan Singh to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations: -

- 1 There are two exit doors provided in the restaurant & both of the door's sizes is less than of the required width of 1.50 mtr each.
- 2 MOEFA found removed.

The above said shortcomings has already been issued and communicated earlier by this department vide letter of even no 198 dated 05/05/2025 & even no 333 dated 08/08/2025.

**In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected.** The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

  
(VIRENDRA SINGH)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

