

C-23

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F.6/DFS/MS/School/2025/SZ/292

Dated: 25/04/2025

To

The Principal,  
Bantam Elementary School,  
Village Rangpuri, New Delhi 110037.

Sub: Regarding issuance of FSC in r/o Bantam Elementary School, located at Village Rangpuri, New Delhi 110037.

Sir,

This has reference to your letter no BES/9/2025 dated 28/02/2025 received through outdoor diary no 13076 dated 03/04/2025 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 16.04.2025 in the presence of Ms. Ritu Guar observed that the school management has constructed 2<sup>nd</sup> & 3<sup>rd</sup> Floor in the existing building. Now the school running at Ground plus Three upper floors. Accordingly fire safety arrangement were tested / checked and found following observation.

1. There are two staircase having width of 1.20 mtr each against the requirement of two staircase having width of 1.50 mtr each.
2. First aid hose reel not provided.
3. Internal hydrant not provided.
4. Terrace level fire fighting pumps capacity 225 LPM provided against the required capacity 450 LPM.
5. Overhead tank capacity 2500 ltrs provided against the required capacity 10,000 ltrs.
6. Exit signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054.