



c/36

75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ 789

Dated: 16 / 06 /2025

FIRE SAFETY CERTIFICATE

Certified that the building of **Basava International School** located at Plot No-1, Sector-23, Dwarka, New Delhi-110075, comprised of **Ground + 03 upper floors**, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/SZ/2021/707 dated 03/09/2021. The premise was re-inspected by the officer concerned of this department on 11/06/2025 in the presence of Ms. Poornima Ambli (G.M) & Ms. Gunjan Malhotra (Principal) and found that said building/premise is fit for occupancy class "**Educational Group B**" (School) with effect from 16 / 06/2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 16 / 06 /2025 at New Delhi by

(ATUL GARG)
DIRECTOR

Ph/011-23414000

01/06/25

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
2. Ms. Poornima Ambli (General Manager), Basava International School located at Plot No-1, Sector-23, Dwarka, New Delhi-110075

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

N-20

INSPECTION REPORT				
1.	Name & address of the building	Basava International School at Plot No-1, Sector-23, , Dwarka New Delhi-110075		
2.	Type of Occupancy	Educational (Group B)		
3.	Building Comprised of	Ground + 03 upper floors		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F6/DFS/MS/SZ/2021/707 dated 03/09/2021		
6.	Fire Safety directives Letter No.	DFS Act 2007/Reles 2010/NBC-IV		
7.	Date of inspection	11/06/2025		
8.	Name of the Inspecting Officer	ADO (DWK)		
9.	Name and designation of Officer from the building side	Ms. Poornima Ambli (G.M) & Ms. Gunjan Malhotra (Principal)		
10.	Year of Construction	2004		
11.	Applicant's letter No.	BIS/Fire NOC/Renewal/2025/06 Dt. 04/06/25 Outdoor Diary No. 2437 dated 04/06/2025		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	03 Nos	03 Nos	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.5 mtr	166m, 1.75m & 1.78m	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	02 Nos	03 Nos	MR
	e. Width of Corridor	1.5m	1.5m to 2.35m	MR
	f. Door Size	1.0m	1.0m to 1.10m	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	12 ACPH	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	ISI Marked	35 Nos	MR
	• Types		ABC & CO ₂	MR
	• ISI marking		Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	02 Nos	02 Nos	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR

N-22

19.	Fire Control Room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	Required	ABC fire extinguisher provided near elect. panel	MR

The fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection. *The shortcomings issued vide letter No. F.6/DFS/MS/School/2025/SZ/509 dated 10/06/25 found complied.*

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/SZ/2021/707 dated 03/09/2021, renewal under rule 37 of Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for perusal/approval & signature please.

[Signature]
Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (DWK)

DO (SW)

[Signature]
12/6/25

[Signature]
12/6/25

[Signature]
Director

[Signature]
13/5/24
Adm/om

Sir, F.T letter is put up for your sig. pl

[Signature]
Director

[Signature]
16/06/25