

296

94
-31

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

No. F.6/DFS/MS/WZ/GH/2025/ 124

Dated: 19/03/2025

To,

Mr. Parveen Kumar,
House No.375, Bhera Enclave,
Paschim Vihar,
New Delhi-110087.

Sub: Renewal of FSC in r/o M/s DB Town House, DO Bhai Estates located at BP-12, West Patel Nagar, Delhi-110008.

Sir,

This is reference to online application no. 2025022102252 dated 25.02.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 10.03.2025, in presence of **Sh. Parveen Chugh (Pwner)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Smoke ventilation grill found removed in corridors.
2. Water tank capacity 5000ltr provided & other tanks found disconnected from pumping system.
3. Terrace fire pumps were not found in auto mode.
4. Terrace found used for open sky lounge/Restaurant.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt
p://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy To:-

1. MCD Portal Id- 2025022102252 dated 25.02.2025