

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110001**

No. F.6/DFS/MS/School/2025/SZ/ 622

Dated: 07/05/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **BDM Public School** located at **A-80 Chattarpur Extn. New Delhi 110074** comprised of Ground plus Three Upper floors was issued FSC by this department vide letter No. F6/DFS/MS/School/2022/SZ/412 Dated 12-04-2022. The premises was re-inspected by officer concerned of this department on 01/05/2025 in presence of Mr. Prateek Rohilla and observed that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class **"Educational Building"** Group-B, as above with effect from 07/05/2025 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/05/2025 at New Delhi by

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. The Principal, BDM Public School located at A-80 Chattarpur Extn. New Delhi -74.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-54.

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

# INSPECTION REPORT

आज़ादी का  
अमृत महोत्सव

1	Name & Address of the Building	BDM Public School, at A-80, Chattarpur Extn. New Delhi 110074.
2	Type of Occupancy	Educational, Group-B (School)
3	Building Comprised of	Ground + 03 upper floors.
4	Type of Case	Renewal
5	Details of Previous NOC	F6/DFS/MS/School/2022/SZ/412 Dated 12-04-2022
6	Fire Safety Directives Letter No	Nil
7	Date of Inspection	01/05/2022
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)
9	Name & Designation of Officers from the building side	Mr. Prateek Rohilla (Manager)
10	Year of construction	2007
11	Applicant letter No.	Email dated 21-04-2025

S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
--------	---	---------------------	------------------	----------------

## 1 Access to Building.

• Road width	6 mtr	5.75 mtr	MR (old case)
• Gate width	4.5 mtr	4.5 mtr	MR
• Width of internal road	-NA-	-NA-	-NA-

## 2 Number, width, type & arrangement of exits.

### a) Number of Staircase

➤ Upper floors.	01 No	02 Nos	MR
➤ Basement floor.	-NA-	-NA-	-NA-

### b) Width of Staircase

➤ Upper floors	1.5 m/0.75m	1.40m & 1.30m	MR (old case)
➤ Basement floor	-NA-	-NA-	-NA-

### c) Protection of exits

➤ Fire check door	-NA-	-NA-	-NA-
➤ Pressurization	-NA-	-NA-	-NA-

### d) No. of continuous staircase to terrace

One	02 Provided	MR
-----	-------------	----

### e) Width of corridor

1.50 m	1.80 m	MR
--------	--------	----

### f) Door size

1 m	Provided	MR
-----	----------	----

## 3 Compartmentation.

• Fire check door.	-NA-	-NA-	-NA-
• Sealing of electrical shafts.	-NA-	-NA-	-NA-
• Fire rating of shaft door.	-NA-	-NA-	-NA-
• Water curtain	-NA-	-NA-	-NA-
• Fire dampers.	-NA-	-NA-	-NA-

## 4 Smoke Management system.

• Basement	30 ACPH	-NA-	-NA-
• Upper floors	12 ACPH	-NA-	-NA-

## 5 Fire Extinguishers.

• Total numbers	Required	16 Nos	MR
• Types	ABC/CO2	ABC & CO2	MR
• ISI Marking	ISI mark	Provided	MR

## 6 First Aid Hose Reels.

• Total numbers on each floor.	One	Provided	MR
• Length of hose-reel hose.	30m	Provided	MR
• Nozzle Diameter	5mm	Provided	MR

## 7 Automatic fire detection & alarming system.

• Type of detectors	-NA-	-NA-	-NA-
	-NA-	-NA-	-NA-





-N	• PA system panel.	-NA-	-NA-	-NA-
-N	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>			-NA-
The fire protection system provided in the building was test checked at random and found functional at the time of inspection.				
Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/School/2022/SZ/412 Dated 12-04-2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.				
Accordingly DFA is put up for approval and signature please.				
<p>Signature of the Inspecting Officer Name: Sh. Rajesh Kumar Design: ADO (BCP)</p>				

DO (SD)

*Miller* *visko*

*cro(mor)*

*5/5/2025*

*Director*

*6/5/25*

*6/5/25*

As approved, F.T. letter is put up  
for your signature A

*6/5*

*Director*

*mu*