



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ 565

Dated: 30/04/2025

FIRE SAFETY CERTIFICATE

Certified that the **BGS International Public School** located at Sector-5, Dwarka, New Delhi-110075, comprised of Basement, Ground + 03 upper floors, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/SZ/2022/205 dated 24/02/2022. The premise was re-inspected by the officer concerned of this department on dated 09/04/2025 in the presence of Sh. Bore Gowda (Admin) and observed that said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "**Educational Group B**" with effect from 30/04/2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/04/2025 at New Delhi by

(ATUL GARG)
DIRECTOR
Ph. 011-23414000
o/c

Copy to: -

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
2. Principal, BGS International Public School at Sector-5, Dwarka, New Delhi-110075

Conditions for the validity of Fire Safety Certificate:

1. **Basement shall not be used for any purpose other than storage as per undertaking dated 09/04/2025. The FSC issued shall be withdrawn in case of non-compliance.**
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection.
4. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
5. All the staff members must know the correct method of operation of fire-fighting system.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, prior to its expiry.
8. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

N-2

INSPECTION REPORT				
1.	Name & address of the building	BGS International Public School located at Sector-05, Dwarka, New Delhi-110075		
2.	Type of occupancy	Educational, Group-B (School)		
3.	Building comprised of	Basement, Ground + 03 upper floors		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F6/DFS/MS/School/SZ/2022/205 Dt. 24/02/2022		
6.	Fire Safety directives letter No.	F6/DFS/MS/BP/2001/2733 dated 24/12/2001		
7.	Date of Inspection	09/04/2025		
8.	Name of the Inspecting Officer	ADO (DWK)		
9.	Name and designation of Officer from the building side.	Sh. Bore Gowda (Admin)		
10.	Year of construction	2001		
11.	Applicant's letter No.	Form 'J' received through outdoor diary No. 15094 dated 28/03/2025		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Requirement As per N/5-8	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	06 mtr	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	➤ Upper floors	03 Nos	05 Nos	MR
	➤ Basements	02 Nos	02 Nos	MR
	b. Width of staircases			
	➤ Upper floors	1.5 mtr each	Provided	MR
	➤ Basements	1.5 mtr each	Provided	MR
	c. Protection of exits			
	➤ Fire check door	NA	NA	NA
	➤ Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	1.5 mtr	Provided	MR
	f. Door Size	1.0 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Managements System			
	• Basements	Required	Exh. Fan provided	MR
	• Upper floors	Required	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers at each floor	25 Nos	Provided	MR
	• Types	ABC & CO ₂	ABC & CO ₂	MR
	• IS marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	03 Nos	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR

N-2

7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	03 Nos.	Provided	MR
	• Hose Box	03 Nos.	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	➤ Discharge of main pump	1620 LPM	Provided	MR
	➤ Head of main pump	40 mtr	Provided	MR
	➤ Number of main pumps	01 No	Provided	MR
	➤ Jockey pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	40 mtr	Provided	MR
	➤ Standby Pump out put	1620 LPM	Provided	MR
	➤ Standby Pump Head	40 mtr	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	30 mtr	30 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for firefighting			
	• Underground tank capacity	50,000 ltrs	Provided	MR
	➤ Draw off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	Provided	MR
	• Overhead Tank capacity	20,000 ltrs	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

N-19

19.	Fire Control Room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	Required	02 ABC fire extinguisher provided near electric panel	MR

The fire protection systems provided in the premises/building were checked, tested at random and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/School/SZ/2022/205 dated 24/02/2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for perusal/approval & signature please.

Santosh Kumar
24.04.25
Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (DWK)

DO (SW)

[Signature]
24/4/25

CFo
26/4/2025

Director

[Signature]
26/4/25

ADO - DWK

[Signature]

*Spoken to ADO/SJ/OW
letter sign.*

FT Ph

[Signature]
26/4/25

*Sir, F.T letter is put up for your sig. pl
Director*
26/4/25