



C/100

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001


No.F6/DFS/MS/School/2026/NDZ/ 16

Dated: 24/01/2026

FIRE SAFETY CERTIFICATE

Certified that the **Bhai Parmanand Vidya Mandir** located at Surya Niketan, Near karkardooma, Delhi-110092, comprised of Basement & Ground + 04 upper floors (New Block) owned/occupied by **Bhai Parmanand Vidya Mandir**. The premises was inspected by the officer concerned of this department on 20/01/2026 in the presence of Sh. Ajay Pal Singh Principal and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have complied with rule 33 of Delhi Fire Service Rules 2010 and that the building/premises is fit for occupancy class 'Educational (Group-B)' with effect from 24/01/2026 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on....24/01/2026.....at New Delhi by.


(Dr. S. K. TOMAR)
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

To,

1. The Commissioner, MCD, Civic Centre, New Delhi: to ensure the occupancy a detailed above.
2. The Dy. Director of Education, D-Block, Anand Vihar, Delhi- 110092
3. The Principal, Bhai Parmanand Vidya Mandir located at Surya Niketan, Near karkardooma, Delhi- 110092.

MCD Id No. **10056628**

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
8. Basement shall be used as per NBC part IV.

N/29

1. Name & address of the building : Bhai Parmanand Vidya Mandir, Surya Niketan, Near karkardooma, Delhi-110092
2. Building is comprised of : Basement & Ground + 04 upper floors (New Block)
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous NOC letter : Nil
6. Fire Safety directive letter No. : F.6/DFS/MS/BP/2020/271 Dated 30/07/2020
7. Date of Inspection : 20/01/2026
8. Name of the Inspecting officers : Deepak Kumar, ADO (TP/Shd.)
9. Name and designation of Officer from the building side : Sh. Ajay Pal Singh (Principal)
10. Year of Construction : 2000 & 2025
11. Applicant's letter No : 10056628 Dated 10/01/2026

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	Directives Requirement	Provided at Site	Remarks MR/NMR
01	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 m 4.50 m 06 m	25 m 05 m x 02 nos. 06 m	MR MR MR
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases <ul style="list-style-type: none"> • Upper Floor • Basement B. Width of Staircases <ul style="list-style-type: none"> • Upper Floor • Basement c. Protection of exits <ul style="list-style-type: none"> • Fire check door • Pressurization d. No. of continuous staircases to terrace e. Width of Corridor f. Door Size	02 nos. N/A 1.50 mtr N/A Required N/A 02 no. 1.50 mtr 01 mtr.	02 nos. N/A 1.50 m each N/A Provided N/A 01 no. 1.50 mtr 01 mtr.	MR N/A MR N/A MR N/A MR
03	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	Required Required Required N/A N/A	Provided Provided Provided N/A N/A	MR MR MR N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	12 ACPH 12 ACPH	Provided Ventilated	MR MR

05.	Fire Extinguishers			
	• Total numbers	18 nos.	20 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR
06	First-aid-Hose Reels.			
	Total numbers on each floor • Length of hose reel hose • Nozzle diameter	02 no.	02 no.	MR
		30 mtr	30 mtr	MR
		05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors • Location of main panel • Location of repeater panel • Alternate source of power • Hooter's location	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	02 nos.	02 nos.	MR
	• Hose Box	02 nos.	02 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	12 nos.	N/A
	• Hose Box	N/A	12 nos.	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➢ Discharge of main Pump	2280 LPM	2280 LPM	MR
	➢ Head of Main Pump	70 m	70 m	MR
	➢ Number of main pumps	01 nos.	01 nos.	MR
	➢ Jockey pump out put	180 LPM	180 LPM	MR
	➢ Jockey pump head	70m	70m	MR
	➢ Standby pump out put	2280 LPM	2280 LPM	MR
	➢ Standby pump Head	70m	70m	MR
	➢ Auto Starting /Manual stopping	Required	Provided	MR
	➢ Pump House Access	Required	Provided	MR
	• Terrace Level			
	➢ Discharge of pump	900 Lpm	900 lpm	MR
	➢ Head of the Pump	40 mtr.	40 mtr	MR
	➢ Power supply	Required	Provided	MR
	➢ Auto Starting of pump	Required	Required	MR

N/31


14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	2,00,00 Ltrs.	2,00,00 Ltrs.	MR
	➢ Draw-off connection	Required	Required	MR
	➢ Fire service inlet	Required	Required	MR
	➢ Access to tank	Required	Required	MR
	• Overhead Tank capacity	25,000 Ltrs.	30,000 Ltrs.	MR
15	Exit Signage.			
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Required	MR
	• Firemen's grounding switch	Required	Required	MR
	• Lift Signage	Required	Required	MR
17	Standby power supply	Required	Required	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	Required	Required	MR
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	Required	Required	MR
	• Battery backup	Required	Required	MR
	• Building Floor Plans	Required	Required	MR
20	Special Fire Protection systems for protection of special Risks, if any:	Required	Required	MR

Note:-"During the inspection, the building was found to have one basement, ground floor plus four upper floors. However, according to the guidelines issued by this department, approval was granted for two basements, ground floor and four upper floors."

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule. **It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.**

Accordingly, DFA is put up for approval and signature please.



21/01/2025

Signature of the Inspecting Officer
Name : - Deepak Kumar
Designation : - A.D.O (TP/Shah.)

DO (ED)



Pr. Dir (N.D.T)



22/01/2026

Pr. Cfo to Secy.



22/01/2026

Bhai Parmanand Vidya Mandir at Surya Niketan, Near karkardooma, Delhi-110092



22/01/2026