



FIRE SAFETY CERTIFICATE

Certified that the **Bharat Public School** located at **J-1/10, Saurabh Vihar, Near Shiv Mandir (Jaitpur), New Delhi**, comprised of **Ground + 03 upper floors**, owned & occupied by **Bharat Public School** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by officer concerned of Delhi Fire Service on 26.05.2025 in the presence of Mrs. Alka Verma (Principal) and found that the building/premises (Ground + 03 upper floors) is fit for occupancy of **Group B "Educational Building" (School)** with effect from **03.06.2025**.... for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on **03.06.2025**....at New Delhi by.


26/05/2025
(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Bharat Public School located at J-1/10, Saurabh Vihar, Near Shiv Mandir (Jaitpur), New Delhi.

Conditions for the validity of Fire Safety Certificate:-

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT				
1	Name & address of the building		Bharat Public School located at J-1/10, Saurabh Vihar, Near Shiv Mandir (Jaitpur), New Delhi.	
2	Building is comprised of		Ground + 03 upper floors	
3	Type of occupancy		Group B –Educational Building	
4	Type of case		New Case	
5	Details of previous FSC		Nil	
6	Fire safety direction letter no.		UBBL-2016/NBC-Part-IV -2016	
7	Date of inspection		26.05.2025	
8	Name of the inspecting officers		Rajesh Kumar Shukla ADO (M. Road)	
9	Name of the designation of officer from the building side		Mrs. Alka Verma (Principal)	
10	Year of construction		2021	
11	Applicant's letter no.		Outdoor diary no. 664 dated 16.04.2025	
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A	Road width	6.0 m	Provided
	B	Gate width	NA	NA
	C	Width of internal road	NA	NA
2	Number, Width, Type and Arrangement of Exits:			
	A	Number of staircases		
	a	Upper floor	02 nos.	03 nos.
	b	Basement	NA	NA
	B	Width of staircases		
	a	Upper floor	1.50 m each	1.50 m & 1.50 m (Iron) & 1.32 m
	b	Basement	NA	NA
	C	Protection of exits		
	a	Fire check door	NA	NA
	b	Pressurization	NA	NA
	D	No. of continuous staircases to terrace	01 no.	01 no.
	E	Width of corridor	1.5 m	Provided
	F	Door size	1.0 m for class room	Provided
3	Compartmentation:			
	A	Fire check door	NA	NA
	B	Sealing of electrical shafts	NA	NA
	C	Fire rating of shaft door	NA	NA
	D	Water curtain	NA	NA
	E	Fire dampers	NA	NA
4	Smoke Management System:			
	A	Basement	NA	NA
	B	Upper floor	Required	Natural
5.	Fire Extinguisher:			
	A	Total numbers	20 nos.	30 nos.
	B	Types	CO ₂ & ABC	CO ₂ & ABC
	C	ISI marking	Required	Provided
6	First-Aid-Hose Reel:			
	A	Total numbers of each floor	02 nos. each floor	02 nos. each floor
	B	Length of hose reel hose	30 m	30 m
	C	Nozzle diameter	5 mm	5 mm

7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	NA	NA	NA
	B	Location of main panel	NA	NA	NA
	C	Location of repeater panel	NA	NA	NA
	D	Alternate source of power	NA	NA	NA
	E	Hooters	NA	NA	NA
8	MOEFA:		NA	NA	NA
9	Public Address System:		NA	Provided	NA
10	Automatic Sprinkler System:				
	A	Basement	NA	NA	NA
	B	Upper floor	NA	NA	NA
	C	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:				
	A	Size of riser/down-comer	NA	NA	NA
	B	Number of hydrants per floor	NA	NA	NA
	C	Hose box	NA	NA	NA
12	Yard Hydrants:				
	A	Total number of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	NA	NA	NA
	B	Head of main pump	NA	NA	NA
	C	Number of main pumps	NA	NA	NA
	D	Jockey pump out put	NA	NA	NA
	E	Jockey pump head	NA	NA	NA
	F	Standby pump out put	NA	NA	NA
	G	Standby pump head	NA	NA	NA
	H	Auto starting /manual stopping	NA	NA	NA
	I	Pump house access	NA	NA	NA
2	Terrace Level				
	A	Discharge of pump	450 LPM	2 nos. of 450 LPM	MR
	B	Head of the pump	40 m	40 m	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting:				
	A	Underground tank capacity	NA	NA	NA
	B	Draw-off connection	NA	NA	NA
	C	Fire service inlet	NA	NA	NA
	D	Access to tank	NA	NA	NA
	E	Overhead tank capacity	10,000 ltrs	10,000 ltrs	MR
15	Exit Signage:		Required	Provided	MR
16	Provision of Lifts:				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Firemen's grounding switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
17	Standby Power Supply:		NA	NA	NA
18	Refuge Area:				
	A	Total area	NA	NA	NA
	B	Location	NA	NA	NA

Bharat Public School located at J-1/10, Saurabh Vihar, Near Shiv Mandir (Jaitpur), New Delhi.


19	Fire Control Room:			
A	Detector system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	PA system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	NA

Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

The shortcomings issued to the school by this department vide letter no. F6/DFS/MS/School/SZ/2022/224 dated 17.05.2022 has been rectified by the management.


Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, it is recommended to grant Fire Safety Certificate under Rules 35 of Delhi Fire Service Rules 2010.


Signature of the Inspecting Officer
Name Rajesh Kumar Shukla
Designation ADO (M. Road)

DO (SD)


20/5/25


29/5/2025



20/5/25

ADO (M.R.)

FI is put up ple


30/5/25

CFO


2/6/2025

M.C. cell