



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6/DFS/MS/2025/School/WZ/ 852

Dated: 03/07/2025

FIRE SAFETY CERTIFICATE

Certified that the **Bharat Shakti Public School, J-51, Krishan Vihar, Delhi-110086**, comprised of **Ground + One upper floor** owned/occupied by **Bharat Shakti Public School** was granted FSC by this department vide letter No. **F.6/DFS/MS/2022/School/WZ/633** dated **13.06.2022**. The premises was re-inspected by the officer concerned of this department on **17.06.2025** in the presence of **Mr. Kapil Solanki (Owner)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from 03/07/2025 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 03/07/2025 at New Delhi


 (Atul Garg)
 DIRECTOR

Ph; 011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Bharat Shakti Public School, J-51, Krishan Vihar, Delhi-110041.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+R](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/) ules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : Bharat Shakti Public School, J-51, Krishan Vihar, Delhi-110086.
2. Type of Occupancy : Educational
3. Comprised of building : Ground + 01 upper floor, 1st floor terrace found under construction given undertaking by school management
4. Type of Case : Renewal (Ground + 01 upper floor)
5. Details of Previous NOC : F.6/DFS/MS/2022/School/WZ/633 dated 13.06.2022
6. Fire Safety directives letter No : Director of Education Cir. dated 01.03.2011
7. Date of inspection : 11.02.2025
8. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
9. Name and designation of officers : Mr. Kapil Solanki (Owner)
10. Year of Construction : OD No.11921 dated 28.01.2025.
11. Applicant's letter No.

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Director of Education Cir. dated 01.03.2011 | Provided at site | Remarks MR/NMR |
|--------|---|---|--------------------------------------|--------------------------------------|
| 1. | Access to building | | | |
| | <ul style="list-style-type: none"> Road width Gate width Width of internal road | Accessible Accessible -NA- | Accessible 4.5m -NA- | MR MR -NA- |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> Upper Floors Basements | 01nos. -NA- | 01nos. -NA- | MR -NA- |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> Upper Floor Basements | 1.5m -NA- | 1.5m -NA- | MR -NA- |
| | c. Protection of exits | | | |
| | Fire check door | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> Pressurization | -NA- | -NA- | -NA- |
| | d. No. of continuous staircases to terrace | 01nos. | 01nos. | MR |
| | e. Width of Corridor | 1.5m | 1.5m | MR |
| | f. Door Size | 1.0m | 1.0m | MR |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers | -NA- -NA- -NA- -NA- -NA- | -NA- -NA- -NA- -NA- -NA- | -NA- -NA- -NA- -NA- -NA- |
| 4. | Smoke Management System | | | |
| | <ul style="list-style-type: none"> Basements Upper floors | -NA- -NA- | -NA- -NA- | -NA- -NA- |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers Types IS marking | 04nos. ABC/CO2 ISI marked | Provided ABC/CO2 Yes | MR MR MR |
| 6. | First-Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | -NA- -NA- -NA- | -NA- -NA- -NA- | -NA- -NA- -NA- |
| 7. | Automatic fire detection and alarming system | | | |
| | <ul style="list-style-type: none"> Type of detectors | -NA- | -NA- | -NA- |

| | | | | |
|-----|--|------|------|------|
| | <ul style="list-style-type: none"> • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location | -NA- | -NA- | -NA- |
| 8. | MOEFA | -NA- | -NA- | -NA- |
| 9. | Public Address System | -NA- | -NA- | -NA- |
| 10. | Automatic Sprinkler System | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> • Basement • Ground & Upper Floors • Sprinkler above false ceiling | -NA- | -NA- | -NA- |
| 11. | Internal Hydrants | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box | -NA- | -NA- | -NA- |
| 12. | Yard Hydrants | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> • Total number of hydrants • Hose Box | -NA- | -NA- | -NA- |
| 13. | Pumping Arrangements | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➢ Discharge of main Pump ➢ Head of Main pump ➢ Number of main pumps ➢ Jockey Pump out put ➢ Jockey pump head ➢ Standby Pump out put ➢ Standby Pump Head ➢ Auto Starting/Manual Stopping ➢ Pump House Access • Terrace level <ul style="list-style-type: none"> ➢ Discharge of pump ➢ Head of the pump ➢ Power Supply ➢ Auto Starting of pump | -NA- | -NA- | -NA- |
| 14. | Captive Water Storage for fire fighting | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➢ Draw-off connection ➢ Fire service inlet ➢ Access to tank • Overhead Tank capacity | -NA- | -NA- | -NA- |
| 15. | Exit Signage. | -NA- | -NA- | -NA- |
| 16. | Provision of Lifts. | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage | -NA- | -NA- | -NA- |
| 17. | Standby power supply | -NA- | -NA- | -NA- |
| 18. | Refuge Area. | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> ➢ Total Area ➢ Location | -NA- | -NA- | -NA- |
| 19. | Fire Control Room | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel | -NA- | -NA- | -NA- |

N/14

| | | | | |
|-----|---|------|------|------|
| | <ul style="list-style-type: none"> PA System Panel Battery backup Building Floor Plans | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | -NA- | -NA- | -NA- |

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in **Director of Education Circular**, the FSC issued vide letter no. **F.6/DFS/MS/2022/School/WZ/633 dated 13.06.2022** is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Ajay
26/6/25

Signature of the Inspecting Officer
Name **Ajay Kumar Sharma**
Designation **ADO (Rohini)**

DO (NW) - on me

DO (WZ)

[Signature]
26/6/2025

DO (WZ) - 172-1112
Dated... 26/6/2025

DO

[Signature]
30/6/2025

Director
[Signature]

[Signature]
11/7/25

[Signature]

FT letter is put up for kind perusal
and signature please.

Director
[Signature]
[Signature]

[Signature]
27/7/25