

C-8

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/2025 / 41

Dated: 23.01.2025

To,

The Manager
M/S Bhartia Guest House,
3439, Dariba Pan, Pahar Ganj,
New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o Bhartia Guest House located at 3439, Dariba Pan, Pahar Ganj, New Delhi.

Sir,

This has reference to on-line ID No. ~~id no~~ 2025010400144 dated 04.01.25, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 15/01/25 in the presence of Mr. Noor and following shortcomings were observed:

1. Smoke management system found nonfunctional .
2. Pump found nonfunctional.
3. Stand by power supply found nonfunctional.

In view of above, the case is rejected and FSC issued earlier stand null and void and renewal cannot be issued at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:

Addl. Commissioner of Police (Lic), 1st floor, Defence Colony Police Station, New Delhi.