



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 175

Dated: 19/02/2025

FIRE SAFETY CERTIFICATE

Certified that the Bhartiya Vidyalaya (Govt. Aided) located at Sindhora Kala, Shakti Nagar Extension, Delhi-110052 comprised of Ground floor only owned/ occupied by Bhartiya Vidyalaya (Govt. Aided) was issued Fire Safety Certificated by this department vide letter no. F6/DFS/MS/School/2022/WZ/354 Dated: 31.03.2022. The premises was inspected by the officer concerned of this department on 11.02.2025 in presence of Smt. Preeti Bhagat (Incharge) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 262-362 dated 17.01.2005 and the building/ premise is fit for occupancy class Group B Educational with effect from19/02/2025 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on19/02/2025 at New Delhi


 (Atul Garg)
 Director

Ph:-011-23414000

Copy to: -

1. The Deputy Director of Education, GNCT of Delhi, Zone-VII, District North Lucknow Road, Timarpur, Delhi - 110054.
2. The Principal, Bhartiya Vidyalaya (Govt. Aided) located at Sindhora Kala, Shakti Nagar Extension, Delhi-110052

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Bhartiya Vidyalaya at Sindhora Kalan, Shakti Nagar Extn., Delhi-110052.
2. Composition of building : Ground floor only
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/2022/WZ/354 Dated: 31.03.2022
6. Fire Safety directives letter No : NA
7. Date of inspection : 11.02.2025
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Mrs. Preeti Bhagat (Principal)
10. Year of Construction : 1985
11. Applicant's letter No. : Online E-mail Dated- 28.01.2025

	Minimum Standards on fire prevention and fire safety U/R 33	D.O.E Circular dated 17.01.2005 Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width 	06m	06m	MR
	<ul style="list-style-type: none"> Gate width 	4.5m	4.5m	MR
	<ul style="list-style-type: none"> Width of internal road 	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors 	NA	NA	NA
	<ul style="list-style-type: none"> Basements 	NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors 	NA	NA	NA
	<ul style="list-style-type: none"> Basements 	NA	NA	NA
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> Pressurization 	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	01m	01m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> Fire Dampers 	NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	NA	NA	NA
	<ul style="list-style-type: none"> Upper floors 	Required	Natural Ventilation	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	02nos	03nos	MR
	<ul style="list-style-type: none"> Types 	ABC/CO2	ABC-03	MR
	<ul style="list-style-type: none"> ISI marking 	ISI Marked	Yes	MR

6	First-Aid Hose Reels.		
	• Total numbers on each floor	NA	NA
	• Length of hose reel hose	NA	NA
	• Nozzle diameter	NA	NA
7	Automatic fire detection and alarming system.		
	• Type of detectors	NA	NA
	• Location of Main Panel	NA	NA
	• Location of Repeater Panel	NA	NA
	• Alternate source of power	NA	NA
	• Hooters' Location	NA	NA
8	MOEFA	NA	NA
9	Public Address System.	NA	NA
10	Automatic Sprinkler System.		
	• Basement	NA	NA
	• Upper Floor	NA	NA
	• Sprinkler above false ceiling	NA	NA
11	Internal Hydrants		
	• Size of riser/down-comer	NA	NA
	• Number of hydrants per floor	NA	NA
	• Hose Box	NA	NA
12	Yard Hydrants.		
	• Total number of hydrants	NA	NA
	• Hose Box	NA	NA
13	Pumping Arrangements.		
	• Ground Level		
	➤ Discharge of main Pump	N/A	N/A
	➤ Head of Main pump	N/A	N/A
	➤ Number of main pumps	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A
	➤ Jockey pump head	N/A	N/A
	➤ Standby Pump out put	N/A	N/A
	➤ Standby Pump Head	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A
	➤ Pump House Access	N/A	N/A
	• Terrace level	N/A	N/A
	➤ Discharge of pump		
	➤ Head of the pump	NA	NA
	➤ Power Supply	NA	NA
	➤ Auto Starting of pump	N/A	N/A
14	Captive Water Storage for fire fighting.		
	• Underground tank capacity	NA	NA

	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 17.01.2005, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. F6/DFS/MS/School/2022/WZ/354 Dated: 31.03.2022.

Signature of the Inspecting Officer
Name :- C.L. Meena
Designation:- ADO/RN

D.B. Mukharjee (DO/NW)

DCFO/.....10/10-11/2025
Dated.....14/2/2025

14/02/2025

14/2/2025

14/2/2025

14/2/2025

Director

14/2/2025

cont. - P.T.O.