



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/11/19
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/Hospital/WZ/2025/373

Dated:- 07/07/2025

FIRE SAFETY CERTIFICATE

Certified that the Bhatia Global Hospital & Endosurgery Institute, located at 305, 307, 308, Ambica Vihar, New Delhi-110087, comprised of Basement + Ground + 03 Upper Floors was issued Fire Safety Certificate vide Letter No. F6/DFS/MS/Hospital/WZ/2022/409 dated 19/09/2022. The said premises was re-inspected by the officer concerned of this department on 24/06/2025 in the presence of Sh. Rakesh (HR) and found that the building/premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010, and that the premises/building is fit for occupancy class "Institutional Building" Group C Sub Division C-1 with effect from 07/07/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 07/07/2025 at New Delhi by.

(Atul Garg)
Director

Tel. No. 011-23414000

Copy to:-

1. Sh. R S Bhatia (Chairman), Bhati Global Hospital & Endosurgery Institue, New Delhi-110087.

Conditions for validity of fire safety certificate:-

1. All the means of escape shall be kept free of all type of obstruction all the time. It should not bolt /locked.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any loss of life any property due to the non-functional of any fire safety measures, management shall be held responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of building Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
9. The basement shall be used as per BBL.

INSPECTION REPORT

1. Name & address of the building : Bhatia Global Hospital & Endosurgery Institute
located at 305-307-308, Ambica Vihar, Paschim Vihar, New Delhi-110087
2. Type of Occupancy : Institutional (Basement + Ground + 03 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/Hospital/WZ/2022/409 dated 19/09/2022
5. Fire Safety directives Letter No. : F6/DFS/MS/2012/85 dated 10.01.2012
6. Date of inspection : 24/06/2025
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
9. from the building side : Sh. Rakesh (HR)
10. Year of Construction : 2001
11. Applicant's letter No. : nil dated 29.05.2025

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements as per directive letter issued dated 10/01/2012/ as per earlier FSC issued dated 19/09/2022	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	05 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	Provided	MR
	• Basements	02	Provided	MR
	b. Width of staircases			
	• Upper floors	2 m	2 m x 2	MR
	• Basements	2 m	2 m x 2	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	Old Case	Old Case	Old Case
	f. Door Size	Old Case	Old Case	Old Case
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	10 nos.	12 nos.	MR
	• Types	DCP & CO2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01 at each floor	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR

7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Ground floor	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	01 each floor	Provided	MR
	• Hose Box	01 each floor	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	1620 lpm	Provided	MR
	• Discharge of main pump	75 m	Provided	MR
	➤ Head of main pump	02	Provided	MR
	➤ Number of main pumps	180 lpm	Provided	MR
	➤ Jockey pump out put	75 m	Provided	MR
	➤ Jockey pump head	1620 lpm	Provided	MR
	➤ Standby Pump out put	75 m	Provided	MR
	➤ Standby Pump Head	Required	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level	NA	NA	NA
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for firefighting:			
	• Under ground tank capacity	50,000 litres	Provided	MR
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 litres	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

19.	Fire control room	NA	NA	NA
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards of fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/Hospital/WZ/2022/409 dated 19/09/2022 is recommended under rule 37 of the Delhi Fire Service Rule, 2010 under DFS Act 2007.

Accordingly DFA is prepared put up for approval please.

[Signature]
26/6/25
Aman Kumar Lathar
ADO (JWP)

[Signature]
26/6/25

[Signature]
26/6/2025

FOI 723/2022
Dated: 26/6/2025

[Signature]
CFO

[Signature]
01/07/2025

Director

[Signature]
1/07/25
Aman Kumar Lathar

Sir,
F.T. letter is put-up for your signature pl,

[Signature]
4/07/25
M

[Signature]
04/07/25
ADO (JWP)