

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001**


No: F6/DFS/MS/EH/WZ/2025/296

Dated: 14/08/2025

**FIRE SAFETY CERTIFICATE**

Certified that the M/s **BIG DADDY CLUB** located at **GF-06C, The City Square Mall, Raja Garden, Delhi - 110027**, in a building comprised of **02 Basements + Ground + 04 upper floors but restaurant is running at ground floor only** was earlier granted FSC by this department vide letter No. **F6/DFS/MS/EH/WZ/2022/96** dated **04.03.2022**. Now, the restaurant premises was re-inspected by the officer concerned of this department on 26.07.2025 in presence of Mr. Satender (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the said premises is fit for occupancy class (Group - D) "**Assembly Building**", restaurant is running at ground floor only, with effect from...**14/08/2025** for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on .....**14/08/2025**.....at New Delhi by

  
**(Virendra Singh)**  
 Chief Fire Officer  
 Delhi Fire Service  
 o/c 8/14/25

**Copy to:-**

1. The Commissioner, Municipal Corporation of Delhi, Dr. SPM Civic Centre, New Delhi - 02. w.r.to ID No. 2025071511397 dated 16.07.2025.
2. The Licensee, M/s **BIG DADDY CLUB** at GF-06C, The City Square Mall, Raja Garden, Delhi-27.

**Conditions for the validity of fire safety certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010.
5. Basement shall be used as per building bye laws.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of authorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub Rule (I) of Rule 37] along with a copy of this Certificate, six month prior to its expiry. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.
8. This FSC is valid for ground floor (restaurant) only.
9. Any flammable material for interior decoration shall strictly be prohibit.



## INSPECTION REPORT

1	Name & address of the building	M/s BIG DADDY CLUB located at GF-06C, The City Square Mall, Raja Garden, Delhi - 110027.		
2	Building is comprised of	02 Basements + Ground + 04 upper floors (But restaurant is running at ground floor only)		
3	Type of occupancy	Assembly (restaurant)		
4	Type of case	Renewal / Name Change		
5	Details of previous FSC	F6/DFS/MS/EH/WZ/2022/96 dated 04.03.2022		
6	Fire safety direction letter no.	Nil		
7	Date of inspection	26.07.2025		
8	Name of the inspecting officers	ADO (SPM)		
9	Name of the designation of officer from the building side	Mr. Satender (Manager)		
10	Year of construction	2010 (as per MHA Portal)		
11	Applicant's letter no.	MCD portal application ID No. 2025071511397 dated 16.07.2025		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement (as per previous NOC dated 04.03.2022)	Provided at Site	Remarks MR/ NMR
1	Access To Building: FSC issued City Square Mall vide letter No.F.6/DFS/MS/WZ/Mall/2023/473 dated 05.10.2023			
	Road width	12 m	Provided	MR
	Gate width	06 m	Provided	MR
	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits:			
	A	Number of staircases		
	a	Upper floor	NA	NA
	b	Basement	NA	NA
	B	Width of staircases		
	a	Upper floor	NA	NA
	b	Basement	NA	NA
	C	Protection of exits		
	a	Fire check door	NA	NA
	b	Pressurization	NA	NA
	D	No. of continuous staircases to terrace	NA	NA
	E	Width of corridor	NA	NA
	F	Door size	1.5 m x 2	Provided
				MR
3	Compartmentation:			
	A	Fire check door	NA	NA
	B	Sealing of electrical shafts	NA	NA
	C	Fire rating of shaft door	NA	NA
	D	Water curtain	NA	NA
	E	Fire dampers	NA	NA
4	Smoke Management System:			
	A	Upper floors	Required	Provided
	B	Basements	NA	NA
				MR
				NA

5.	<b>Fire Extinguisher:</b>				
	A	Total numbers	05 nos.	Provided	MR
	B	Types	ABC& Co2	ABC& Co2	MR
	C	ISI marking	Required	Provided	MR
6	<b>First-Aid-Hose Reels: Common with Mall</b>				
	A	Total numbers at each floor	01 no.	Provided	MR
	B	Length of hose reel hose	30 mtr.	Provided	MR
	C	Nozzle diameter	05 mm	Provided	MR
7	<b>Automatic Fire Detection And Alarming System:</b>				
	A	Type of detectors	NA	NA	NA
	B	Location of main panel	NA	NA	NA
	C	Location of repeater panel	NA	NA	NA
	D	Alternate source of power	NA	NA	NA
	E	Hooters Location	NA	NA	NA
8	<b>MOEFA:</b>		Required	Provided	MR
9	<b>Public Address System:</b>		NA	NA	NA
10	<b>Automatic Sprinkler System:</b>				
	A	Basement	NA	NA	NA
	B	Ground floor	NA	NA	NA
	C	Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants: Common with Mall</b>				
	A	size of riser/down-comer	100 mm	Provided	MR
	B	Number of hydrants per floor	01 no.	Provided	MR
	C	Hose box	01 no.	Provided	MR
12	<b>Yard Hydrants:</b>				
	A	Total number of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	<b>Pumping Arrangements:</b>				
	A	Ground level			
	a)	Discharge of main pump	NA	NA	NA
	b)	Head of main pump	NA	NA	NA
	c)	Number of main pumps	NA	NA	NA
	d)	Jockey pump out put	NA	NA	NA
	e)	Jockey pump head	NA	NA	NA
	f)	Standby pump out put	NA	NA	NA
	g)	Standby pump head	NA	NA	NA
	h)	Auto starting /manual stopping	NA	NA	NA
	i	Pump House Access	NA	NA	NA
	<b>B Terrace level</b>				
	a)	Discharge of pump	450 LPM	Common with Mall	MR
	b)	Head of the pump	40 m	Common with Mall	MR
	c)	Power supply	Required	Common with Mall	MR
	d)	Auto starting of pump	Required	Common with Mall	MR



14	<b>Captive Water Storage For Fire Fighting: Common with Mall</b>			
	A	Underground tank capacity	NA	NA
	B	Draw-off connection	NA	NA
	C	Fire service inlet	Required	Provided
	D	Access to tank	NA	NA
	E	Overhead tank capacity	20,000 ltrs.	Provided
15	<b>Exit Signage:</b>		Required	Provided
16	<b>Provision of Lifts:</b>		Required	Provided
	A	Pressurization of lift shaft	NA	NA
	B	Pressurization of lift lobby	NA	NA
	C	Communication in lift car	NA	NA
	D	Firemen's grounding switch	NA	NA
	E	Lift signage	NA	NA
17	<b>Standby Power Supply:</b>		Required	Provided
18	<b>Refuge Area:</b>			
	A	Total area	NA	NA
	B	Location	NA	NA
19	<b>Fire Control Room :</b>			
	A	Detector system panel	Required	Provided
	B	Flow switch panel	NA	NA
	C	Pa system panel	NA	NA
	D	Battery backup	NA	NA
	E	Building floor plans	NA	NA
20	<b>Special Fire Protection Systems For Protection of Special Risks, If Any:</b>		NA	NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standard of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/EH/WZ/2022/96 dated 04.03.2022 is recommended to be renewed (restaurant is running at ground floor only), under Rule 35 of the Delhi Fire Service Rules 2010.

Accordingly, DFA is put for approval and signature please.

*Sumit Kumar*  
05/08/2025

Signature of the Inspecting Officer  
Name Sumit Kumar  
Designation ADO (SPM)

Dy. CPO (WZ)

*[Signature]*  
05/08/2025

*CFO/*  
*[Signature]*  
11/8/2025

*Principal Director*

*CFO to Genl.*  
*[Signature]*  
12/08/25

*CFO/*  
*[Signature]*

*[Signature]*

*[Signature]*