



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001



No.F6/DFS/MS/Bnqt/2026/NDZ/ 495

Dated: 26/05/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Bliss and Blessing Banquet (A Unit of GRT Fusion Pvt. Ltd.,) is running on ground floor of the building comprised of ground plus one upper floor at located at **Ground floor, Jhilmil Metro Station Complex, Delhi -110095.**, owned/occupied by M/s GRT Fusion Pvt. Ltd., was issued FSC vide letter No. F.6/DFS/MS/BNQT./2022/NDZ/241 dated 30/05/2022. The premises was re-inspected by the officer concerned of this department on dated 14/05/2026 in the presence of Sh. Sanjay Panday, Manager and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy Group 'D' "Assembly Building" (Ground floor) with effect from 26/05/2026 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on.....26/05/2026.....at New Delhi by

26/5/26

(Dr. S. K. TOMAR)
CHIEF FIRE OFFICER
DELHI FIRE OFFICER

O/c

To:-

1. The Commissioner, MCD, Civic Centre, New Delhi: to ensure the occupancy a detailed above.
2. Sh. Gaurav Kapoor, M/s Bliss and Blessing Banquet (A Unit of GRT Fusion Pvt. Ltd.,)
 Ground floor, Jhilmil Metro Station Complex, Delhi -110095.
 MCD ID NO2026050506390

Conditions for the validity of Fire Safety Certificate:-

1. FSC is valid for ground floor only.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : **M/s Bliss and Blessings Banquet located Ground floor at PD Area of Jhilmil Metro Station, Delhi-110095**
2. Building is comprised of : Ground plus one upper floor but banquet is running at ground floor only.
3. Type of Occupancy : Assembly Building
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/BNQT./2022/NDZ/241 dated 30/05/2022
6. Fire Safety directive letter No. : F.6/DFS/MS/2020/2026 dated 28/10/2020 (for Metro)
7. Date of Inspection : 14/05/2026
8. Name of the Inspecting officers : Deepak Kumar, ADO (TP)
9. Name and designation of Officer from the building side : Sh. Sanjay Panday
10. Year of Construction : 2022
11. Applicant's letter No : 2026050506390 dated 05/05/2026

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	06 m	30 m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	02 m	02 m x 03	MR
	g. No. of Doors	02 nos.	03 nos.	MR
03	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	02 hrs	Provided	MR
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	Provided	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Provided	MR
05.	Fire Extinguishers			
	• Total numbers	10 nos.	12 nos.	MR
	• Types	ABC /CO ₂	ABC & CO ₂	MR
	• IS marking	ISI marked	Provided	MR

06	First-Aid-Hose Reels.	Common with Metro Station		
	Total numbers on each Branch	01 nos	02 nos	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.	Common with Metro		
	• Type of detectors	Heat & Smoke	Heat & Smoke	N/A
	• Location of main panel	Ground floor	Provided	N/A
	• Location of repeater panel	N/A	Provided	N/A
	• Alternate source of power	Battery & DG set	Provided	N/A
	• Hooter	Required	Provided	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.	Common with Metro		
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	Provided	N/A
	• sprinkler above false ceiling	N/A	Provided	N/A
11	Internal Hydrants	Common with Metro		
	• size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per Branch	01 nos.	Provided	MR
	• Hose box	01 nos.	Provided	MR
12	Yard Hydrants.	• Total number of hydrants	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.	Common with Metro		
	➤ Ground Level	• Discharge of main pump	N/A	2850 lpm
		• Head of main pump	N/A	60 M
		• Number of main pumps	N/A	01nos
		• Jockey pump out put	N/A	180 LPM
		• Jockey pump head	N/A	70 M
		• Standby pump out put	N/A	2850 lpm
		• Standby pump head	N/A	60 M
		• Auto starting /manual stopping	N/A	Provided
		• Pump house access	N/A	Provided
	➤ Terrace Level	• Discharge of pump	900 Imp	900 Imp
		• Head of the pump	60 M	60 M
		• Power supply	Required	Provided
		• Auto starting of pump	Required	Provided
14	Captive Water Storage for Fire Fighting.	Common with Metro		
	• Underground tank capacity	N/A	2,00,000 ltr	N/A
	• Draw-off connection	N/A	Provided	N/A
	• Fire service inlet	N/A	Provided	N/A
	• Access to tank	N/A	Provided	N/A
	• Overhead tank capacity	20,000 ltr	20,000 ltr	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The Fire protection system provided in the building were tested and checked and found functional at the time of Inspection. The earlier shortcomings issued vide letter no F.6/DFS/MS/Banq./2025/NDZ/610 dated 15/12/2025 has been rectified now.

Keeping in view, the deemed compliance of the minimum standards on Fire prevention and Fire safety measures as required under the rule. The Fire safety Certificate issued vide Letter No. F.6/DFS/MS/BNQT./2022/NDZ/241 dated 30/05/2022 **renewal under Rules 35 of the Delhi Fire Service Rules 2010 is recommended.**

Last Date 03/06/2026

Deepak
14/05/2026
Signature of the Inspecting Officer
Name : Deepak Kumar
Designation : A.D.O. (TP)

D.O.(E/D) . *J. Miller* 14/5/26

CFO (NDZ) *A. Kumar* 14/5/26

Principal Director

Cfo to *Deepak*

CFO (NDZ)

15/05/26

A.D.O. (TP)
18/5/26