

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ 664

Dated: ..16/05/2025

FIRE SAFETY CERTIFICATE

Certified that the **Birla Vidya Niketan School** (Higher Secondary & Primary Block) located at Pushp Vihar, Sector-IV, New Delhi-110017 comprised of 02 Building Blocks (Basement, Ground plus Three Upper floors each) owned/occupied by Birla Academy of Art and Culture was issued FSC by this department vide letter No. F.6/MS/DFS/School/2022/SZ/408 dated 12-04-2022 for Higher Sec. Block & F6/DFS/MS/School/2022/SZ/309 dated 23/03/2022 for primary Block. The premises was re-inspected by officer concerned by this department on 07/05/2025 in the presence of Mr. C.L. Mishra (Manager-Admin) of the school and observed that the school premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class **"Educational"** Group-B (School) as above with effect from16/05/2025 for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of conditions mentioned below.

Issued 16/05/2025 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. Mr. C.L. Mishra (Manager-Admin) Birla Vidya Niketan, Pushp Vihar-IV, New Delhi-110017
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The basement shall be used as per the provisions of BBL-/NBC Part- IV.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	Birla Vidya Niketan School (Higher Secondary School & Primary Block), Pushp Vihar, Sector-IV, New Delhi-110017		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Both of Blocks are Basement, Ground + 03 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/MS/DFS/School/2022/SZ/408 dated 12-04-2022 for Higher Sec. Block F6/DFS/MS/School/2022/SZ/309 dated 23/03/2022 for primary Block		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/2013/13 dated 21/03/2013		
7	Date of Inspection	07-05-2025		
8	Name of the Inspecting Officers.	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. C.L. Mishra (Manager-Admin)		
10	Year of construction	2015		
11	Applicant letter No.	Email dated 02-04-2025		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	9 mtr	12 mtr	MR
	• Gate width	6 mtr/4.5 mtr	Provided	MR
	• Width of internal road	6 mtr	Provided	MR
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	05 Nos each blk	Provided	MR
	➤ Basement floor.	03 Nos each blk	Provided	MR
	b) Width of Staircase			
	➤ Upper floors	1.5m each blk	1.58m, 1.50m, 1.50m, 1.50 & 1.40m GF to 2 nd Floor- 2m (Canteen Block)	MR
	➤ Basement floor	1.5m each blk	1.52m, 1.50m & 1.50m	MR
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	01 No	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1m	Provided	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	30 ACPH	Provided exhaust fan	MR
	• Upper floors	12 ACPH	Natural Ventilation	MR
5	Fire Extinguishers.			
	• Total numbers	ISI marked	40 Nos each blk	MR
	• Types		ABC & CO2	MR
	• ISI Marking		Provided	MR

N/29

6	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	Hose-reel	BF-03, UF-04 Nos	MR
			30m each	MR
			5mm each	MR
7	Automatic fire detection & alarming system. For higher Secondary block			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Required	Smoke type	MR
		Required	Ground floor	MR
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Every floor	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System	Required	Provided	MR
		For higher Secondary block		
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	Required	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11	Internal Hydrants.	For higher Secondary block		
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	150 mm	Provided	MR
		04 Nos	Provided	MR
		04 Nos	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		1620 & 2 x 450 LPM	1620 & 2 x 450 LPM	MR
		40m & 35m	40m & 35m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		25,000 Ltr & 15,000 ltrs	25,000 Ltr & 25,000 ltrs	MR
		Required	Provided	MR
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

N/30

17	• Fireman's switch. • Lift signage.	Required	Provided	MR
		Required	Provided	MR
17	Standby Power Supply	Required	Provided (DG set)	MR
18	Refuge Area			
18	• Total area • Location	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19.	Fire Control Room.			
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.			-NA-

The Fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/MS/DFS/School/2022/SZ/408 dated 12-04-2022 for Higher Sec. Block & F6/DFS/MS/School/2022/SZ/309 dated 23/03/2022 for primary Block renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

Accordingly DFA is put up for approval and signature please.

[Signature]

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (SD)

[Signature] 9/5/25
CRO (MS)
13/5/2025

[Signature]
13/5/25

[Signature]

As approved, F.T letter is sent for your signature @

[Signature]
13/5/25