

C-59

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2025/SZ/171
To

Dated: 16.04.2025

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony,
New Delhi 110049.

Sub: Regarding issuance of FSC in r/o M/s Blessing Inn located at Plot No 4, LSC Complex, Police Line, Pitampura, New Delhi 110034.

Sir,


This has reference with **MCD Portal ID 2025031103286 dated 26/03/2025** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 05.04.2025 in the presence of Mr. Subhash (Manager) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Smoke ventilation system not provided in the building as per clause 7.31 of UBBL 2016.
2. First aid hose reel provided but found non-functional.
3. Carbon Monoxide detector provided but found non-functional.
4. MOEFA not working.
5. Public Address system provided but found non-functional.
6. Terrace level fire fighting pumps capacity 450 LPM provided but found non-functional.
7. Exit Signage found removed at some places.

The same observations has already been issued and communicated earlier by this department vide letter of even no 85 dated 15/02/2025.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(VIRENDRA SINGH)
CHIEF FIRE OFFICER
FOR DIRECTOR
DELHI FIRE SERVICE

