



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

C-52  
75  
आज़ादी का  
अमृत महोत्सव

No. F6/DFS/MS/BNQT/NDZ/2025/ 106

Dated: 06/06/2025

To,

Mr. Shankar (Manager),  
M/s Blessing The Banquet (A Unit of Radiant Cold Drinks Pvt. Ltd.),  
Plot No. 09, Road No. 42, Community Center, Pitampura,  
Delhi - 110034.

**Sub: - Regarding grant of Fire Safety Certificate in r/o M/s Blessing The Banquet (A Unit of Radiant Cold Drinks Pvt. Ltd.) located at Plot No. 09, Road No. 42, Community Center, Pitampura, Delhi - 110034**

Sir,

This has a reference to your MHA Portal application No. 2025051508497 dated 17/05/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 24/05/2025 in the presence of Mr. Shankar (Manager) and observed that building comprised of Basement, ground plus one upper floor but banquet hall is running on ground floor only.

**Following shortcomings were observed during time of inspection:**

1. Banquet hall found operational in basement & ground floor and kitchen in first floor with temporary shed. Whereas banquet hall is permitted only in ground floor.
2. Additional temporary construction on first floor shall be demolished.
3. Smoke management system in basement floor found non functional.
4. MOEFA found provided but not functional.
5. P.A system found provided but not functional.
6. Terrace level pump of capacity 450 LPM provided against the requirement of 900 LPM.

In view of above shortcomings, the application for issuance for Fire Safety Certificate at this stage is rejected. The occupancy of the building/premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier.

Yours faithfully,

*Virendra Singh*  
5/6/2025

(VIRENDRA SINGH)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

**Copy to: -**

1. The Joint Commissioner of police (Lic), 1<sup>st</sup> Floor, P. S. Defence Colony, New Delhi-110024. w.e.f.- MCD Portal application No. 2025051508497 dated 17/05/2025.
2. The Dy. Health Officer, Keshavpuram Zone, A-1, Public Health Department, MCD, Keshavpuram, Delhi-110035.