

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/2025/199

Dated 23/04/2025

FIRE SAFETY CERTIFICATE

Certified that the **Blood Bank at Dr. R.M.L Hospital, New Delhi**, is comprised of **Ground + 02 Upper floors** and temporary rooms at terrace floor will not used as per undertaking letter no. 12-04/2025/RMLH/MS/77 dated 15.04.2025. The premises was inspected by officers concerned of this department on 07/04/25 in the presence of Sh. Mohit (JE), Sh. Omprakash (AE) and found that the said building has complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the permanent structure premises is fit for occupancy class- **hospital building (ground and two upper floor)** with effect from **23/04/2025**. for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010 printed below.

Issued 23/04/2025 at New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. Dr. (Prof.) Ajay Shukla , Director & Medical Superintendent, R.M.L. Hospital, Baba Kharag Singh Marg, New Delhi
2. The Executive Engineer (E), RML Hospital, Baba Kharag Singh Marg, New Delhi.
3. The Chief Architect, NDMC, Palika Kendra, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Pending work as submitted vide letter no. 12-04/2025/RMLH/MS/77 dated 15.04.2025 that CTVS department shall be shifted to New SSB block within 04 month and temporary floor will not be used for any purpose.
10. **Further, this FSC is valid only for permanent structure.**

INSPECTION REPORT

1. Name & address of the building : Blood Bank at Dr. R.M.L. Hospital, New Delhi.
2. Type of occupancy : Hospital Building (Gr. + 02 Upper floors) + temporary rooms at terrace floor
3. Type of case:- : Fresh (12 point inspection)
4. Details of previous FSC : N/A
5. Fire safety directives No. : N/A
6. Date of inspection:- 07/04/25
7. Name of the inspecting officer : Sh. Rajinder Atwal DO/CD,
Sh. Ravinder Singh ADO/CC
8. Name & designation of officer
From the building side : Sh. Mohit (JE), Sh. Omprakash (AE)
9. Year of construction : old building
10. Applicant's letter No : AE (E)-II/Dr.RML/Hosp/E.D/2024-25/12
dated 24.02.2025.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 mtr.	13 mtr.	MR
	2) Gate width	4.5 mtr.	4.5mtr.	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 No.	02 No.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.36 mtr. & .75 mtr	1.50 & 1.20 m	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01 No.	01 No.	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	N/A	N/A
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	16Nos.	Provided	MR
	2) Types	ABC & CO2	ABC, CO2 & W.CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each	02	Provided	MR

	2) Length of hose reel hose	30 m	Provided	MR
	3) Nozzle diameter	5mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors (smoke)	Required	Provided	MR
	2) Location of main panel	gr. Floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100mm	Provided	MR
	2) Number of hydrants per floor	02 nos	Provided	MR
	3) Hose box each floor	02 nos	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	02 nos	Provided	MR
	2) Hose box	02 nos	Provided	MR
13.	Pumping Arrangement	Common pump rooms for entire complex		
	1) Ground level			
	a) Discharge of main pump	2850LPM	Provided	MR
	b) Head of main pump	45 m	Provided	MR
	c) Number of main pump	02	Provided	MR
	d) Jockey pump out put (2 Nos.)	02 nos	Provided	MR
	e) Jockey pump head	40m	Provided	MR
	f) Stand by pump output	2850 LPM	Provided	MR
	g) Stand by pump head	45m	Provided	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level	N/A	N/A	N/A
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting: feeding with main line			


21/7

	1) Under ground tank capacity	50,000 ltr.	2,50,000 ltr.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	10,000Lts	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a. Detector system panel	N/A	N/A	N/A
	b. Flow switch panel	N/A	N/A	N/A
	c. PA system panel	N/A	N/A	N/A
	d. Battery backup	N/A	N/A	N/A
	e. Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection. Further, an undertaking has been submitted by hospital authority vide letter no. 12-04/2025/RMLH/MS/77 dated 15.04.2025 placed on file that temporary floor will not be used for any purpose and CTVS department shall be shifted to New SSB block ~~with~~ within 04 month, accordingly, if agreed, we may accept the same.

In view of the compliance of the minimum standards of fire prevention and fire safety measures as per recommendations under the rules, if agreed, we may issue the FSC to said hospital (Blood Bank). Accordingly, DFA is prepared and put up for kind perusal/approval and signature please.

Signature of the inspecting officer



 21/4/25

Name: - Rajinder Atwal
Designation: - DO (CD)

Signature of the Inspecting Officer

 21/4/25

Name: Ravinder Singh
Designation: ADO (CC)

 C.F.O.
 23/4/2025
Director
KAM

 D.A.S.