

2/144

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/2025/ 55

Dated: 31/01/2025

To,

The Joint Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi. [adlcp.lic-dl@nic.in](mailto:adlcp.lic-dl@nic.in).

Sub: Regarding renewal of fire safety certificate in r/o M/s. Bloom Hotel, Located at 17A./32,33 & 34, Main Gururdwara Road, Opposite Jessa Ram Hospital, Karol Bagh, New Delhi-110005.

Sir,

Please refer to your MHA Portal ID No. -2025010400167 dated 04/01/2025, on the subject cited above. In this connection, it is to inform you that the premises/building was inspected by the officer concerned by this department on 24/01/2025 in the presence of Sh. Gireesh Kumar to check the shortcomings already issued vide letter no. F6/DFS/MS/GH/2025/01 dated 01/01/2025. The Status of the Shortcoming is as under:-

S. no.	Shortcomings	Status
1.	Carbon monoxide detectors are not provided in building.	Rectified
2.	Sealing of electric shaft not provided.	Not Rectified
3.	Smoke management system are not provided.	Not Rectified
4.	Goods lifts is required to be protected by fire check door or fire curtain at each level.	Not Rectified
5.	Fire protection system shall be required in electric panel room which is situated on the 4 <sup>th</sup> floor.	Not Rectified

In view of above, application for renewal of fire safety certificate is not considered at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,

(Atul Garg)

Director

Copy To: -

1. The Executive Engineer (Building), MCD, Karol Bagh Zone, Anand Parbat, New Delhi. (Email Id: - [eePWDdelhim132@gmail.com](mailto:eePWDdelhim132@gmail.com))
2. The Authorized Signatory, M/s. Bloom Hotel, 17A./32,33 & 34, Main Gururdwara Road, Opposite Jessa Ram Hospital, Karol Bagh, New Delhi-110005. Online No. -2025010400167 dated 04/01/2025